



1. Compression fit details that incorporate GenFlex Water Stop must have all existing flashing removed to the bare substrate, e.g. masonry block.
2. Metal coping cap, expansion joint, and edge details are typical only. All metal work should be installed to sheet metal codes (SMACNA). Clean all metal prior to installation of GenFlex materials.
3. Polymer batten strips cannot be used for attachments into masonry wall substrates. Use only on smooth surfaces, e.g. wood or insulation.
4. When EPDM is used on wall or curb flashing, vertical seams must be stripped-in at the base of angle change with 6" (152 mm) strip of Uncured EPDM Flashing, or 7" (177.80 mm) Peel & Stick. See Detail E-3.01.
5. All parapet walls and roof curbs must be suitable for flashing, e.g. clean, tight, smooth, no cracks, etc.



Wall Termination with Counter-Flashing

EPDM Systems

ACCEPTABLE SYSTEMS:
All Roof Systems

MAXIMUM WARRANTY: **20 Years**

ISSUE / REVISION
DATE:
6-22-2015

NOT TO SCALE

DETAIL NO.

E-1.02