



1. Metal coping cap, expansion joint, and edge details are typical only. All metalwork should be installed to sheet metal codes (SMACNA). Clean all metal prior to installation of GenFlex materials.
2. All wood nailers to be approved material. Attachment of wood nailer to be accomplished by using fasteners providing no less than 125 lb (556 N) of pullout resistance per linear foot, with fastener spacing no greater than 24" (610 mm) between fasteners.
3. All parapet walls and roof curbs must be suitable for flashing, e.g. clean, tight, smooth, no cracks, etc.
4. When field membrane is used as wall or curb flashing, vertical seams must be stripped-in at base of angle change with a 6" (152 mm) wide strip of Uncured EPDM Flashing, or 7" (178 mm) Peel & Stick Flashing. See Detail E-3.01.



**Coping Termination Over Membrane Flashing**

EPDM Systems

ACCEPTABLE SYSTEMS:  
All Roof Systems

MAXIMUM WARRANTY: **20 Years**

ISSUE / REVISION  
DATE:  
6-22-2015

DETAIL NO.

**E-1.04**

NOT TO SCALE