



Side View of Field Wrapped Pipe

Base wrap to extend 1" Min. (25 mm) up vertical surface of pipe and 2" Min. (51 mm) onto field membrane with a solid hot air weld to the deck membrane.

Upper wrap to extend 1 1/2" (38 mm) onto base wrap and 8" Min. (203 mm) up pipe and sealed into a bead of GenFlex Water Stop with a stainless steel compression band.

See membrane securement note on Detail T-7.01. Securement must occur outside of boot flashing area for this condition.



Field Fabricated Pipe Wrap	
EZ TPO Systems	ACCEPTABLE SYSTEMS: All

MAXIMUM WARRANTY: 20 Years	ISSUE / REVISION DATE: 10-27-2015
	DETAIL NO. EZ-7.02