



**NOTE:**

1. REFER TO GENFLEX WEBSITE FOR THE MOST CURRENT INFORMATION.
2. HOLE IN MEMBRANE SHOULD EXTEND A MINIMUM OF 1/2" (13 mm) BEYOND CLAMPING RING AND SHOULD BE LARGER THAN THE DIAMETER OF THE LEADER PIPE.
3. INSULATION ADJACENT TO DRAIN TO BE APPROPRIATE GENFLEX INSULATION WITH APPROPRIATE BONDING SURFACE.
4. GENFLEX WATERSTOP MIN 1/2 OF 10 OZ. (295 ml) TUBE PER 4" DRAIN. USE ADDITIONAL WATERSTOP FOR LARGER DRAINS.
5. IN REROOF APPLICATIONS:
  - REMOVE EXISTING FLASHING DOWN TO METAL BOWL.
  - REPAIR OR REPLACE BROKEN DRAIN COMPONENTS.
  - DRILL AND TAP BROKEN DRAIN BOLTS AND REPLACE IF NECESSARY.

**SUMP AREA FIELD SEAM REQUIREMENTS**

- A. IF SEAM EDGE IS WITHIN 9" (229 mm) OF DRAIN COMPRESSION RING, EPDM TARGET PATCH IS REQUIRED.
- B. IF SEAM EDGE IS WITHIN 9" (229 mm) TO 18" (457 mm) OF DRAIN COMPRESSION RING, INSTALL A LAYER OF 7" (178 mm) PEEL & STICK FLASHING CENTERED OVER SEAM EDGE. EXTEND FLASHING 3" (76 mm) MIN. BEYOND EDGE OF SUMP.



**ROOF DRAIN**

**GENFLEX™**

ACCEPTABLE SYSTEMS: **SEAM2SEAM™ EPDM**

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/06/2020

DETAIL NO.

**S2S-D-1**

GENFLEX: (800) 443-4272 www.genflex.com

NOT TO SCALE