



CONTINUOUS BEAD OF SEAM2SEAM SEALANT (REQUIRED)

DRIP / GRAVEL STOP EDGE (SEE NOTE #4)

7" (178 mm) PEEL & STICK FLASHING

SEAM2SEAM SEALANT (SEE NOTE #3)

PEEL & STICK T-JOINT COVER

7" (178 mm) PEEL & STICK FLASHING

1-1/4" HOT DIPPED GALVANIZED ROOF NAILS AT 4" (102 mm) O.C. MAX. STAGGERED 1/2" (13 mm)

- NOTE:**
1. REFER TO GENFLEX WEBSITE FOR THE MOST CURRENT INFORMATION.
 2. APPLY SEAM2SEAM SEALANT ALONG ENTIRE PERIMETER OF T-JOINT COVER. REFER TO S2S-IS-9 FOR PEEL & STICK EDGE TREATMENT.
 3. SEAM2SEAM SEALANT IS REQUIRED ALONG ENTIRE UPSLOPE EDGE OF PEEL & STICK FLASHING WHEN ROOF SLOPE IS 1" (25 mm) PER FOOT OR GREATER.
 4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
 5. USE ACCEPTABLE SEAM2SEAM PRIMER TO CLEAN AND PRIME EPDM MATING SURFACES PRIOR TO INSTALLATION OF PEEL & STICK PRODUCTS.



ROOF EDGE INSIDE / OUTSIDE CORNER WITH PEEL & STICK FLASHING AND T-JOINT PATCH

GENFLEX™ SEAM2SEAM™ EPDM

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

06/12/2020

DETAIL NO.

S2S-RE-26

NOT TO SCALE