


- NOTE:
1. REFER TO GENFLEX WEBSITE FOR MOST CURRENT INFORMATION.
 2. METAL COUNTER-FLASHING IS NOT REQUIRED IF MEMBRANE EXTENDS UP AND OVER CURB WALL PRIOR TO INSTALLATION OF R.T.U.
 3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (8 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE MOUNTED TIGHTLY TO UNDERSIDE OF MECHANICAL UNIT.
 4. GENFAST FASTENERS WITH TERMINATION CAULK OVER FASTENER HEADS. TERMINATION CAULK ALSO REQUIRED ALONG ENTIRE EDGE OF CURB FLANGE.
 5. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 lb PER LINEAR FOOT IN ANY GIVING DIRECTION
 6. USE ACCEPTABLE GENFLEX PRIMER TO CLEAN AND PRIME EPDM MATING SURFACES PRIOR TO REMOVAL OF SEAM2SEAM SEAM RELEASE LINER.
 7. SEAM2SEAM SEALANT IS REQUIRED OVER ALL FIELD AND FLASHING SEAMS.
 8. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

	TERMINATION AT R.T.U. WITH COUNTER-FLASHING UNIT FLANGE ABOVE MEMBRANE		MAXIMUM WARRANTY: 20 Years	
	GENFLEX™	ACCEPTABLE SYSTEMS: SEAM2SEAM™ EPDM		ISSUE / REVISION DATE: 04/06/2020
GENFLEX: (800) 443-4272 www.genflex.com				DETAIL NO. S2S-T-15
				NOT TO SCALE