



**NOTE:**

1. REFER TO GENFLEX WEBSITE FOR MOST CURRENT INFORMATION.
2. APPLY WATERSTOP IN A 3/8" (10 mm) TO 1/2" (13 mm) BEAD AT APPROXIMATELY 10 IF PER TUBE.
3. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANT REQUIRED. NOT INCLUDED AS PART OF THE GENFLEX WARRANTY.
4. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (8 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
5. INSTALL GENFAST TERMINATION BAR WITH 1/4" (6 mm) GAP BETWEEN ADJOINING SECTIONS.
6. TERMINATION BAR MUST BE CUT AT INSIDE AND OUTSIDE CORNERS. **DO NOT BEND AROUND CORNERS.**
7. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25 mm) MAX. OF ALL SECTION ENDS.
8. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS

**MASONRY AND CONCRETE WALLS / CURBS MUST BE WATERPROOFED AND MAINTAINED IN ORDER FOR ANY SURFACE MOUNTED TERMINATION TO BE EFFECTIVE.**



**TERMINATION WITH REGLET COUNTERFLASHING AND TERMINATION BAR**

**GENFLEX™**

ACCEPTABLE SYSTEMS: **SEAM2SEAM™ EPDM**

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/06/2020

NOT TO SCALE

DETAIL NO.

**S2S-T-4**