



NOTE:

1. REFER TO GENFLEX WEBSITE FOR MOST CURRENT INFORMATION.
2. REGULAR MAINTENANCE OF COUNTERFLASHING AND SEALANT REQUIRED. NOT INCLUDED AS PART OF THE GENFLEX WARRANTY.
3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (8 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
4. INSTALL GENFAST TERMINATION BAR WITH 1/4" (6 mm) GAP BETWEEN ADJOINING SECTIONS.
5. TERMINATION BAR MUST BE CUT AT INSIDE AND OUTSIDE CORNERS. **DO NOT BEND AROUND CORNERS.**
6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25 mm) MAX. OF ALL SECTION ENDS.
7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
8. APPLY WATERSTOP IN A 3/8" (10 mm) TO 1/2" (13 mm) BEAD AT APPROXIMATELY 10 LF PER TUBE.

**MASONRY AND CONCRETE
WALLS / CURBS MUST BE
WATERPROOFED AND
MAINTAINED IN ORDER
FOR ANY SURFACE
MOUNTED TERMINATION
TO BE EFFECTIVE.**



**TERMINATION WITH SURFACE MOUNTED
COUNTERFLASHING AND TERMINATION BAR**

GENFLEX™

ACCEPTABLE SYSTEMS: **SEAM2SEAM™ EPDM**

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:

04/06/2020

DETAIL NO.

S2S-T-6

GENFLEX: (800) 443-4272 www.genflex.com

NOT TO SCALE