



**NOTE:**

1. REFER TO GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANTS REQUIRED. NOT INCLUDED AS PART OF THE GENFLEX WARRANTY.
3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
4. INSTALL GENFAST TERMINATION BAR WITH 1/4" (6.35 mm) GAP BETWEEN ADJOINING SECTIONS.
5. GENFAST TERMINATION BAR MUST BE CUT AT INSIDE AND INSIDE CORNERS. DO NOT BEND AROUND CORNERS.
6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25.4 mm) MAX. OF ALL SECTION ENDS.
7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
8. GENFLEX EZ TPO PEEL & STICK CAN BE USED AS VERTICAL WALL FLASHING IN LIEU OF STANDARD GENFLEX EZ TPO. MEMBRANE ADHESIVE IS NOT REQUIRED WHEN EZ TPO PEEL & STICK MEMBRANE IS USED. SEE DETAIL EZT-PS-WF-01.
9. APPROVED PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN EZ TPO PEEL & STICK MEMBRANE IS USED FOR FLASHING.
10. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES.
11. IF INTERMEDIATE ATTACHMENT IS REQUIRED, COMPLETE AS FOLLOWS:
  - UP TO 5' (1.52 m) WALL HEIGHT- NONE REQUIRED
  - 5' (1.52 m) - 10' (3.05 m) WALL HEIGHT - ONE ATTACHMENT AT 1/2 THE WALL HEIGHT
  - ABOVE 10' (3.05 m) - ONE ATTACHMENT EVERY 3' (0.91 m)

**MASONRY AND CONCRETE WALLS / CURBS MUST BE WATERPROOFED AND MAINTAINED IN ORDER FOR ANY SURFACE MOUNTED TERMINATION TO BE EFFECTIVE**



**TERMINATION WITH SURFACE-MOUNTED COUNTER-FLASHING AND TERMINATION BAR**

ACCEPTABLE SYSTEMS: EZ TPO PEEL & STICK™

ACCEPTABLE SYSTEMS: EZ TPO PEEL & STICK™ SELF ADHERED

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

05/01/2023

DETAIL NO.

EZT-PS-T-01

NOT TO SCALE