



NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. REFER TO DETAIL EZT-PS-LS-01 FOR WELD WIDTH.
3. MAXIMUM 10" (254 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENT).
6. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-PS-LS-04 FOR CUT EDGE SEALANT APPLICATION.
7. REFER TO GENFLEX TIS SHEETS AND APPLICATION GUIDES FOR LIST OF COMPATIBLE SUBSTRATES WITH GENFLEX EZ TPO PEEL & STICK MEMBRANE.
8. ACCEPTABLE 0.060" (1.52 mm) EZ TPO MEMBRANE WITH APPROPRIATE GENFLEX MEMBRANE ADHESIVE CAN BE USED AS VERTICAL WALL FLASHING IN LIEU OF GENFLEX EZ TPO PEEL & STICK MEMBRANE. MEMBRANE ADHESIVE IS NOT REQUIRED WHEN EZ TPO PEEL & STICK MEMBRANE IS USED. SEE DETAIL EZT-PS-WF-01.
9. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
10. APPROVED PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN EZ TPO PEEL & STICK IS USED FOR FLASHING.
11. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES

MASONRY AND CONCRETE WALLS / CURBS MUST BE WATERPROOFED AND MAINTAINED IN ORDER FOR ANY SURFACE MOUNTED TERMINATION TO BE EFFECTIVE



**TERMINATION AT R.T.U.
(UNIT FLANGE ABOVE MEMBRANE)**

ACCEPTABLE SYSTEMS: EZ TPO PEEL & STICK™

ACCEPTABLE SYSTEMS: EZ TPO PEEL & STICK™ SELF ADHERED

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

05/01/2023

DETAIL NO.

EZT-PS-T-12

(800) 443-4272 www.genflex.com

NOT TO SCALE