



NOTE:

1. REFER TO GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANT REQUIRED. NOT INCLUDED AS PART OF THE GENFLEX WARRANTY.
3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
4. INSTALL GENFLEX TERMINATION BAR WITH 1/4" (6 mm) GAP BETWEEN ADJOINING SECTIONS.
5. TERMINATION BAR MUST BE CUT AT INSIDE AND OUTSIDE CORNERS. **DO NOT BEND AROUND CORNERS.**
6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25 mm) MAX. OF ALL SECTION ENDS.
7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
8. IF INTERMEDIATE ATTACHMENT IS REQUIRED, COMPLETE AS FOLLOWS:
  - UP TO 5' (1.5 m) - 10' (3.05 m) WALL HEIGHT-NONE REQUIRED.
  - UP TO 5' (1.5 m) - 10' (3.05 m) WALL HEIGHT-ONE ATTACHMENT AT 1/2 THE WALL HEIGHT.
  - ABOVE 10' (3.05 m) -ONE ATTACHMENT EVERY 3' (0.91 m).
9. APPROVED PRIMER REQUIRED ON ALL VERTICAL SURFACES.



**TERMINATION WITH SURFACE MOUNTED COUNTER-FLASHING AND TERMINATION BAR**

ACCEPTABLE SYSTEMS: EZ EPDM PEEL & STICK™ SELF ADHERED

(800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

07/28/2023

NOT TO SCALE

DETAIL NO.

EZE-PS-T-01