



- NOTE:
1. REFER TO GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
  2. NAILING AND METAL COUNTER-FLASHING ARE NOT REQUIRED IF MEMBRANE IS RUN UP AND OVER CURB WALL PRIOR TO INSTALLATION OF R.T.U.
  3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE MOUNTED TIGHTLY TO UNDERSIDE OF MECHANICAL UNIT.
  4. GENFLEX FASTENER WITH TERMINATION CAULK OVER FASTENER HEADS. TERMINATION CAULK ALSO REQUIRED ALONG ENTIRE EDGE OF CURB FLANGE.
  5. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
  6. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
  7. APPROVED PRIMERS INCLUDE GENPRIME AND ALL PURPOSE LVOC PRIMER.
  9. APPROVED PRIMER REQUIRED ON ALL VERTICAL SURFACES.



**TERMINATION AT R.T.U. WITH COUNTER-FLASHING  
(UNIT FLANGE ABOVE MEMBRANE)**

ACCEPTABLE SYSTEMS: EZ EPDM PEEL & STICK™ SELF ADHERED

(800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years	
ISSUE / REVISION DATE: 07/28/2023	DETAIL NO. EZE-PS-T-07
NOT TO SCALE	