



NOTE:

1. REFER TO WWW.GENFLEX.COM FOR MOST CURRENT INFORMATION.
2. THIS DETAIL MUST BE USED ONLY WHERE THERE IS ANY POSSIBILITY THAT DIFFERENTIAL MOVEMENT WILL OCCUR BETWEEN THE DECK AND A VERTICAL SURFACE. THE WOOD MEMBERS MUST NOT BE FASTENED TO THE WALL.
3. WOOD NAILERS MUST BE INSTALLED WITH SUITABLE FASTENERS TO MEET APPLICABLE BUILDING CODES.
4. ALL SHEET METAL IS TO BE INSTALLED PER SMACNA GUIDELINES.
5. GRANULES MUST BE EMBEDDED WHEN THERMALLY FUSING GRANULE SURFACED CAP SHEET.
6. FLASHING LAPS MUST BE OFFSET FROM FIELD LAPS BY A MINIMUM OF 12" (305 mm).
7. IF FLASHING MUST EXTEND 36" (914 mm) ABOVE ROOF, SEE DETAIL MB-BT-9 OR MB-BT-10.
8. IF THE PARAPET EXCEEDS 18" (457 mm) IN HEIGHT, HOT ASPHALT MUST NOT BE USED TO ATTACH FLASHING.
9. PARAPETS WITH NAILABLE SUBSTRATES MUST HAVE A GENFLEX BASE SHEET MECHANICALLY ATTACHED IN ACCORDANCE WITH THE FOLLOWING SPACING:

UP TO 24" (305-610 mm)	9" (152 mm) ON CENTERS
24-36" (610-914 mm)	6" (228 mm) ON CENTERS
FIELD OF WALL	ONE PER FT ² (929 cm ²)



**BASE FLASHING FOR NON WALL
SUPPORTED DECK**

GENFLEX™

ACCEPTABLE SYSTEMS: **MODIFIED BITUMEN**

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:

05/07/2025

NOT TO SCALE

DETAIL NO.

MB-BT-2