



NOTE:

1. REFER TO WWW.GENFLEX.COM FOR MOST CURRENT INFORMATION.
2. THIS DETAIL SHOULD BE USED ONLY WHERE THE DECK IS SUPPORTED BY THE OUTSIDE WALL.
3. WOOD NAILERS MUST BE INSTALLED WITH SUITABLE FASTENERS TO MEET APPLICABLE BUILDING CODES.
4. ALL SHEET METAL IS TO BE INSTALLED PER SMACNA GUIDELINES.
5. GRANULES MUST BE EMBEDDED WHEN THERMALLY FUSING GRANULE SURFACED CAP SHEET.
6. FLASHING LAPS MUST BE OFFSET FROM FIELD LAPS BY A MINIMUM OF 12" (305 mm).
7. IF FLASHING MUST EXTEND 36" (914 mm) ABOVE ROOF, SEE DETAIL MB-BT-9 OR MB-BT-10.
8. IF THE PARAPET EXCEEDS 18" (457 mm) IN HEIGHT, HOT ASPHALT MUST NOT BE USED TO ATTACH FLASHING.
9. PARAPETS WITH NAILABLE SUBSTRATES MUST HAVE A GENFLEX BASE SHEET MECHANICALLY ATTACHED IN ACCORDANCE WITH THE FOLLOWING SPACING:

UP TO 24" (305-610 mm)	9" (152 mm) ON CENTERS
24-36" (610-914 mm)	6" (228 mm) ON CENTERS
FIELD OF WALL	ONE PER FT ² (929 cm ²)



METAL COPING CAP AND BASE FLASHING

GENFLEX™

ACCEPTABLE SYSTEMS: **MODIFIED BITUMEN**

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:

05/07/2025

NOT TO SCALE

DETAIL NO.

MB-BT-5