

NOTE:

1. REFER TO WWW.GENFLEX.COM FOR MOST CURRENT INFORMATION.
2. REFER TO DETAILS MB-LS-1, MB-LS-2, & MB-LS-3 FOR APPROPRIATE LAP SEALING APPLICATIONS.
3. ALL SHEET METAL IS TO BE INSTALLED PER SMACNA GUIDELINES.

GENFLEX POURABLE SEALER MIN 2" THICK
COVERAGE ABOVE NON-SHRINK GROUT

NON-SHRINK GROUT (BY OTHERS)

4" (152 mm) MIN FLANGE SET
IN GENFLEX MULTI-PURPOSE
MB FLASHING CEMENT OVER FIELD PLIES
(PRIME FLANGE BEFORE STRIPPING)

GRANULE SURFACED
MODIFIED BITUMEN CAP SHEET

INTERPLY REQUIRED FOR
15 & 20 YEAR SYSTEMS

GRANULE SURFACED MODIFIED
BITUMEN CAP SHEET

BASE AND INTERPLY SHEETS AS
REQUIRED FOR DESIRED WARRANTY

1" MIN

1" MIN

PENETRATIONS MUST HAVE PRIMER APPLIED ABOVE
THE HEIGHT OF THE FINISHED POURABLE SEALER

SHEET METAL PITCH PAN,
SOLDERED/WELDED WATERTIGHT

MULTI-PURPOSE MB FLASHING CEMENT
OR AP SEALANT

4" (102 mm) MIN

3" (76 mm) MIN

3" (76 mm) MIN

COVERBOARD (AS REQUIRED)

INSULATION

INSULATION

SUBSTRATE

PENETRATION

PENETRATION

NON-SHRINKING GROUT

COVERBOARD (AS REQUIRED)

INSULATION

INSULATION

SUBSTRATE



PENETRATION POCKET

GENFLEX™

ACCEPTABLE SYSTEMS: **MODIFIED BITUMEN**

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:

05/21/2025

NOT TO SCALE

DETAIL NO.

MB-P-4