

## Product Evaluation

RC668 | 0925

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** RC-668

**Effective Date:** September 1, 2025

**Re-evaluation Date:** September 2029

**Product name:** Elevate UltraPly TPO and GenFlex EZ TPO Roofing Systems Installed over Steel Roof Decks

**Manufacturer:** Amrize Building Envelope LLC  
26 Century Blvd  
Suite 205  
Nashville, TN 37214  
(800)428-4511

### General Description:

#### Elevate Product Description:

- **UltraPly TPO** roof membranes are nominal 0.045" to 0.080" thick flexible TPO (thermoplastic olefin) sheets
- **UltraPly TPO XR 100** roof membranes are nominal 0.045" thick flexible TPO (thermoplastic olefin) sheets
- **UltraPly TPO XR 115** roof membranes are nominal 0.060" thick flexible TPO (thermoplastic olefin) sheets
- **UltraPly TPO XR 135** roof membranes are nominal 0.080" thick flexible TPO (thermoplastic olefin) sheets
- **UltraPly TPO SA** roof membranes are nominal 0.045" to 0.060" thick heat weldable flexible TPO (thermoplastic olefin) sheets
- **MB Base** is a fiberglass reinforced, asphalt-coated base sheet

**Elevate Product Description (Continued):**

- **SBS Base-P** is a fiberglass reinforced, SBS modified bitumen membrane with a sanded bottom and sanded top surface
- **SBS Base** is a fiberglass reinforced, SBS modified bitumen membrane with a sanded bottom and sanded top surface
- **SBS PolyBase** is a polyester reinforced, SBS modified bitumen membrane with a sanded bottom and sanded top surface
- **V-Force** is a vapor barrier, self-adhered membrane
- **UltraPly Bonding Adhesive** is a solvent-based contact adhesive
- **Water Based Bonding Adhesive-P** is a contact adhesive used for bonding Elevate UltraPly TPO membranes to acceptable substrates
- **Single-Ply LVOC Bonding Adhesive** is a solvent-based formulation used for bonding Elevate UltraPly TPO membranes to acceptable substrates
- **Single-Ply LVOC Bonding Adhesive 1168** is a bonding adhesive used for bonding Elevate UltraPly TPO membranes to acceptable substrates
- **XR Bonding Adhesive** is a solvent-based contact adhesive
- **XR Stick Membrane Adhesive** is a two-component, low-rise polyurethane adhesive
- **I.S.O. FIX II** is a single component, moisture cured, polyurethane adhesive
- **I.S.O. Stick** is a two-component, low-rise polyurethane insulation adhesive
- **I.S.O. Twin Pack Insulation Adhesive** is a two-component, low-rise polyurethane adhesive
- **I.S.O. Spray R** is a two-component, low-rise polyurethane adhesive
- **SA-Solvent Based (SB) Primer** is a solvent-based primer to prepare porous substrates to receive V-Force Vapor Barrier Membrane
- **SA-Water Based (WB) Primer** is a polymer emulsion-based primer used in various substrates to enhance the adhesion of V-Force Vapor Barrier Membrane
- **Elevate All-Purpose Fastener** is a roofing fastener for wood and steel decks
- **Elevate All-Purpose S Fastener** is a roofing fastener for wood and steel decks
- **Elevate Heavy Duty** is a #15 Fastener for steel, wood, or concrete decks
- **Elevate Heavy Duty Plus** is a #21 Fastener for wood, steel, or concrete decks
- **Elevate HD Seam Plate** is an AZ55 or AZ50 galvalume insulation plate
- **Elevate HD Plus Seam Plate** is an AZ55 or AZ50 galvalume TPO membrane plate
- **Elevate Insulation Fastening Plate** is a 3" diameter, 0.017 to 0.023" thick galvalume stress plate for base sheet and insulation attachment
- **UltraPly TPO InvisiWeld Plate** is a primer coated plate for use with heat welded TPO membranes
- **UltraPly TPO InvisiWeld-S Plate** is a primer coated plate for use with heat welded TPO membranes
- **Pre-Assembled Fastener and Plate** is a #12 steel fastener with an AZ-50 galvalume steel plate used in all Elevate roof systems to pre-attach insulation or base sheets to steel and wood decks
- **Pre-Assembled Heavy-Duty Fastener and Insulation Plate** is a #15 steel fastener with an AZ-50 galvalume steel plate used in all Elevate roof systems to pre-attach insulation or base sheets to steel and wood decks.

**Elevate Product Description (Continued):**

- **Concrete Drive Fastener** is a steel fastener used for attachment into structural concrete substrates
- **Elevate Polymer Batten Strip** is used for anchoring Elevate membranes and flashing details
- **UltraPly QuickSeam R.M.A. Strip** is a 10" wide UltraPly TPO membrane with two 3" wide strips of tape factory laminated to it along its length
- **AP AccuTrac Kits** are used in roofing applications for the attachment of insulation to steel and wood roof decks with OMG AccuTrac installation equipment
- **Two Piece Impact Nail** is a two-piece factory assembled fastener
- **LWC Base-Ply Fastener** is a base ply fastening system for lightweight concrete decks
- **ISO 95+ GL** is a polyisocyanurate foam insulation
- **ISOGARD HD** is a high-density polyisocyanurate foam with a coated fiberglass facer
- **ISOGARD HD Composite** is a polyisocyanurate foam core laminated to a ½" ISOGARD HD board, with coated fiberglass facers
- **RESISTA** is a polyisocyanurate foam core laminated to a coated fiberglass facer

**GenFlex Product Description:**

- **EZ TPO** roof membranes are nominal 0.045" to 0.080" thick flexible TPO (thermoplastic olefin) sheets
- **GenFlex EZ Fleece Backed TPO (45-mil)** roof membrane nominal 0.045" thick flexible TPO (thermoplastic olefin) sheets
- **GenFlex EZ Fleece Backed TPO (60-mil)** roof membrane nominal 0.060" thick flexible TPO (thermoplastic olefin) sheets
- **GenFlex EZ Fleece Backed TPO (80-mil)** roof membrane nominal 0.080" thick flexible TPO (thermoplastic olefin) sheets
- **EZ TPO Peel and Stick HW** roof membranes are nominal 0.045" to 0.060" thick heat weldable flexible TPO (thermoplastic olefin) sheets
- **EZ TPO Bonding Adhesive** is a solvent-based contact adhesive
- **GenFlex Water Based Bonding Adhesive (P)** is a contact adhesive used for bonding GenFlex TPO membranes to acceptable substrates
- **EZ TPO Bonding Adhesive LVOC** is a solvent-based formulation used for bonding GenFlex TPO membranes to acceptable substrates
- **EZ TPO Bonding Adhesive LVOC 1168** is a bonding adhesive used for bonding GenFlex TPO membranes to acceptable substrates
- **GenFlex Fleece Backed Bonding Adhesive** is a solvent-based contact adhesive
- **GenFlex I.S.O. FIX II** is a single component, moisture cured, polyurethane adhesive
- **GenFlex One Step Insulation Adhesive** is a two-component, low-rise polyurethane adhesive
- **GenFlex ISO Bond Insulation Adhesive** is a two-component, low-rise polyurethane adhesive
- **EZ TPO InvisiWeld Plate** is a primer coated plate for use with heat welded TPO membranes
- **EZ TPO InvisiWeld Plate-S** is a primer coated plate for use with heat welded TPO membranes
- **GenFlex ISO Insulation** is a polyisocyanurate foam insulation
- **GenFlex HD ISO** is a high-density polyisocyanurate foam with a coated fiberglass facer

**GenFlex Product Description (Continued):**

- **GenFlex HD Composite ISO** is a polyisocyanurate foam core laminated to a 1/2" HD ISO board, with coated fiberglass facers
- **Coated Glass Facer** is a polyisocyanurate foam core laminated to a coated fiberglass facer

**Coverboards:**

- **DensDeck and DensDeck Prime** are a fiberglass faced, water-resistant gypsum core coverboard manufactured by Georgia-Pacific Gypsum, LLC
- **SECUROCK Glass Mat Roof Board** is a water-resistant gypsum core coverboard manufactured by US Gypsum Corporation.
- **SECUROCK Gypsum-Fiber Roof Board** is a water-resistant gypsum core coverboard manufactured by US Gypsum Corporation.

**Limitations and Installation:**

**Roof Framing:** The maximum allowable spacing of the roof framing must be as specified in this evaluation report.

**Roof Deck:** For new applications, the roof deck must be secured to the roof framing to resist the required uplift loads.

**Positive Drainage of Roof Deck:** Roof decks, in which this product is to be installed upon, must be provided with positive drainage. A minimum roof slope after construction of 1/4" per foot is recommended.

**Design Wind Pressures:** The design wind uplift pressures must be specified in the assemblies listed in this evaluation report.

**Installation Over an Existing Roof Covering (Roof Recover):**

**Acceptable Applications:** The TPO roofing system may be installed over an existing built-up roof covering or an existing TPO roof covering based on the requirements set forth in this product evaluation report.

- **Inspection of Roof Covering Recover Installation:** Inspection of the roof covering recover installation must be by a Texas Department of Insurance appointed engineer. The Texas Department of Insurance appointed engineer must determine if the roof framing can support the com

**Roof Covering Replacement Versus Roof Covering Recover:** All existing roof coverings must be completely removed and a new roof covering installed if any of the following conditions occur:

- The existing roof or roof covering is water soaked or has deteriorated to the point that the existing roof or roof covering is not adequate as a base for the additional roof covering.
- The existing roof has two or more applications of any type of roof covering.

**Positive Drainage:** The roof covering recover application must not be required to meet the minimum roof slope of 1/4" per foot if positive drainage is provided.

**Roof Framing:** The maximum allowable spacing of the roof framing must be as specified in this evaluation report.

**Roof Deck:** The existing roof deck must be as specified in each assembly listed in this evaluation report. The underside of the roof deck must be examined by the Texas Department of Insurance appointed engineer for corrosion or deterioration. If corrosion exists, then it must be treated with a rust inhibitor. A fastener withdrawal resistance test must be conducted in the corroded or deteriorated area to determine if the withdrawal resistance of the fastener complies with the minimum fastener requirements for the roof covering recover application. If the tested fastener fails to comply, then the deteriorated roof deck must be replaced.

**Fastener Withdrawal Resistance:** The fastener withdrawal resistance must be conducted in accordance with ANSI/SPRI FX-1-2006 and this evaluation report. Fasteners used for the installation of the roof covering recover to the existing roof deck must be as specified in the Installation Instructions section of this evaluation report. For the withdrawal test, the fasteners must be installed in the existing roof deck as required for the roof covering recover installation. A Texas Department of Insurance appointed engineer must review the data to verify the integrity of the existing roof deck and to compare results of the withdrawal tests with the minimum fastener requirements for the roof covering recover application.

The Texas Department of Insurance appointed engineer must document all test results, including the locations on the roof surface where the tests are performed. A minimum of 10 withdrawal resistance tests are required for a roof area up to 50,000 square feet (a minimum of 50 percent of the tests must be conducted at the perimeter and the corners). Five additional tests are required for each additional 5,000 square feet of roof area or portion thereof (a minimum of 50 percent of the tests must be conducted at the perimeter and the corners). The tests must be located evenly spread across the surface of the roof. At least one withdrawal test must be performed on each roof level if the roof consists of multiple levels.

The withdrawal resistance of each tested fastener must comply with the minimum fastener requirements for the roof covering recover application. If a tested fastener fails to comply, then the Texas Department of Insurance appointed engineer must examine that area for deterioration of the roof deck by removing the existing roof covering in that area. If that area of the roof deck has deteriorated, then the deteriorated roof deck must be replaced.

**Existing Roof Covering Preparation:** The existing roof covering must be prepared to receive the roof covering recover as specified in the Elevate installation instructions.

- The existing roof covering surface must be dry and free of dirt and debris.
- If the existing roof covering is gravel surfaced, then the loose gravel must be completely removed. The surface of the existing roof covering must be relatively smooth.

- If the existing roof covering has blisters, buckles, ridges, folds, or other deformations, then they must be removed, and the surface patched to provide a smooth surface.
- If the existing roof covering has loose fasteners, then the existing membrane must be cut open, the loose fasteners removed, and the surface patched to provide a smooth surface.

**Roof Covering Recover Installation:** Installation of the roof covering recover must be specified in the Installation Instructions section of this evaluation report.

**General installation Requirements:**

All International Residential Code (IRC) and the International Building Code (IBC) requirements must be satisfied, and manufacturer's installation instructions followed, unless otherwise specified by this product evaluation.

**Membrane Attachment:** The membrane must be mechanically attached to the roof deck through the insulation board using the fasteners and plates specified in this evaluation report. The fasteners must be placed through the fastening tabs unless otherwise noted in this evaluation report. Also, the membrane must be fully adhered using the adhesives specified in this evaluation report. The following two lap types are used:

**Standard Lap:** The standard lap consists of a 2" wide lap for fully adhered systems, and a 6" wide lap for mechanically attached membranes. Both laps are to be sealed with a minimum 1.5" heat weld.

**Fasteners:** Fasteners must be of sufficient length to penetrate through the steel deck.

**Installation:** Installation must be in accordance with the following assemblies:

Installation:

Name	Definition
System	A – Fully adhered systems B – Adhered base insulation, mechanically fastened top insulation, adhered membrane C – Mechanically fastened insulation, adhered membrane D – Mechanically fastened membrane E – Non-insulated, fastened membrane F – Non-insulated, adhered membrane
AP Fasteners & Plates	Elevate All-Purpose or All-Purpose S Fasteners and Insulation Fastening Plates
HD Fasteners & Plates	Elevate Heavy-Duty Fasteners and HD Seam Plates
HD Fasteners & Insulation Plates	Elevate Heavy-Duty Fasteners and Insulation Fastening Plates
HD Plus Fasteners & Plates	Elevate Heavy-Duty Plus Fasteners with Elevate HD Plus Seam Plates
CD Fasteners & Plates	Elevate Concrete Drive and Insulation Fastening Plates
CD Fasteners & Seam Plates	
Cover Board	One layer of any of the following products: -Georgia-Pacific DensDeck -Georgia-Pacific DensDeck Prime -Elevate ISOGARD HD -USG SECUROCK Glass-Mat Roof Board -USG SECUROCK Gypsum-Fiber Roof Board
Cover Board II	One layer of any of the following products: -Georgia-Pacific DensDeck -Georgia-Pacific DensDeck Prime -USG SECUROCK Glass-Mat Roof Board -USG SECUROCK Gypsum-Fiber Roof Board

Name	Definition		
Insulation	One of more layers in any combination of the following products: -ISO 95+ GL -ISOGARD HD -ISOGARD HD Composite -RESISTA		
Deck Detail	As Tested deck construction details are described as follows:		
	<table border="1"> <tr> <td data-bbox="430 464 653 492">Gypsum</td> <td data-bbox="653 464 1894 492">Poured gypsum; Minimum 2" thickness</td> </tr> </table>	Gypsum	Poured gypsum; Minimum 2" thickness
	Gypsum	Poured gypsum; Minimum 2" thickness	
	<table border="1"> <tr> <td data-bbox="430 498 653 526">Concrete Deck</td> <td data-bbox="653 498 1894 526">Min. <math>f_c = 2,500</math> psi at 28 days</td> </tr> </table>	Concrete Deck	Min. $f_c = 2,500$ psi at 28 days
	Concrete Deck	Min. $f_c = 2,500$ psi at 28 days	
	<table border="1"> <tr> <td data-bbox="430 532 653 560">CWF Deck</td> <td data-bbox="653 532 1894 560">Min. 2.5" thick Tectum I cementitious wood fiber panels</td> </tr> </table>	CWF Deck	Min. 2.5" thick Tectum I cementitious wood fiber panels
	CWF Deck	Min. 2.5" thick Tectum I cementitious wood fiber panels	
	<table border="1"> <tr> <td data-bbox="430 566 653 634">Steel Deck</td> <td data-bbox="653 566 1894 634">                     Min. 22 ga, Wide Rib Deck (Type WR) conforming to ANSI/SDI-RD1.0 &amp; FBC; 0.5% Vented and ASTM A653 G90 for LWIC applications only. The following nomenclature is used to further describe the As Tested condition.                 </td> </tr> </table>	Steel Deck	Min. 22 ga, Wide Rib Deck (Type WR) conforming to ANSI/SDI-RD1.0 & FBC; 0.5% Vented and ASTM A653 G90 for LWIC applications only. The following nomenclature is used to further describe the As Tested condition.
	Steel Deck	Min. 22 ga, Wide Rib Deck (Type WR) conforming to ANSI/SDI-RD1.0 & FBC; 0.5% Vented and ASTM A653 G90 for LWIC applications only. The following nomenclature is used to further describe the As Tested condition.	
	<table border="1"> <tr> <td data-bbox="430 641 653 709">F&lt;#&gt;</td> <td data-bbox="653 641 1894 709">&lt;#&gt; #12-24 HWH self-drilling screws or equivalent fastener at each flute used to secure the deck to the structural supports; Min. 0.25" penetration</td> </tr> </table>	F<#>	<#> #12-24 HWH self-drilling screws or equivalent fastener at each flute used to secure the deck to the structural supports; Min. 0.25" penetration
	F<#>	<#> #12-24 HWH self-drilling screws or equivalent fastener at each flute used to secure the deck to the structural supports; Min. 0.25" penetration	
	<table border="1"> <tr> <td data-bbox="430 716 653 743">G&lt;#&gt;</td> <td data-bbox="653 716 1894 743">Min. Grade &lt;#&gt; of Steel Deck</td> </tr> </table>	G<#>	Min. Grade <#> of Steel Deck
	G<#>	Min. Grade <#> of Steel Deck	
	<table border="1"> <tr> <td data-bbox="430 750 653 777">HS&lt;#&gt;</td> <td data-bbox="653 750 1894 777">Hilti S-SLC 01 M HWH screws or equivalent fastener secured &lt;#&gt;-inch o.c. along the panel side laps</td> </tr> </table>	HS<#>	Hilti S-SLC 01 M HWH screws or equivalent fastener secured <#>-inch o.c. along the panel side laps
	HS<#>	Hilti S-SLC 01 M HWH screws or equivalent fastener secured <#>-inch o.c. along the panel side laps	
	<table border="1"> <tr> <td data-bbox="430 784 653 852">HXE&lt;#&gt;</td> <td data-bbox="653 784 1894 852">&lt;#&gt; Hilti X-ENP 19 L 15 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration</td> </tr> </table>	HXE<#>	<#> Hilti X-ENP 19 L 15 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration
	HXE<#>	<#> Hilti X-ENP 19 L 15 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration	
<table border="1"> <tr> <td data-bbox="430 859 653 927">HXH&lt;#&gt;</td> <td data-bbox="653 859 1894 927">&lt;#&gt; Hilti X-HSN 24 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration</td> </tr> </table>	HXH<#>	<#> Hilti X-HSN 24 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration	
HXH<#>	<#> Hilti X-HSN 24 powder-driven fasteners or equivalent at each flute used to secure the deck to the structural supports; Min. 0.25" penetration		
<table border="1"> <tr> <td data-bbox="430 933 653 961">L&lt;#&gt;</td> <td data-bbox="653 933 1894 961">Max. span of &lt;#&gt; ft.</td> </tr> </table>	L<#>	Max. span of <#> ft.	
L<#>	Max. span of <#> ft.		
<table border="1"> <tr> <td data-bbox="430 967 653 1036">P</td> <td data-bbox="653 967 1894 1036">Min. 5/8-inch diameter puddle welds at each flute used to secure the deck to the structural supports</td> </tr> </table>	P	Min. 5/8-inch diameter puddle welds at each flute used to secure the deck to the structural supports	
P	Min. 5/8-inch diameter puddle welds at each flute used to secure the deck to the structural supports		
<table border="1"> <tr> <td data-bbox="430 1042 653 1110">PW</td> <td data-bbox="653 1042 1894 1110">Min. 5/8" diameter puddle welds with weld washers at each flute used to secure the deck to the structural supports</td> </tr> </table>	PW	Min. 5/8" diameter puddle welds with weld washers at each flute used to secure the deck to the structural supports	
PW	Min. 5/8" diameter puddle welds with weld washers at each flute used to secure the deck to the structural supports		
<table border="1"> <tr> <td data-bbox="430 1117 653 1185">S&lt;#&gt;</td> <td data-bbox="653 1117 1894 1185">1/4"-14 HWH x 7/8" self-drilling screws or equivalent fastener secured &lt;#&gt;-inch o.c. along the panel side laps</td> </tr> </table>	S<#>	1/4"-14 HWH x 7/8" self-drilling screws or equivalent fastener secured <#>-inch o.c. along the panel side laps	
S<#>	1/4"-14 HWH x 7/8" self-drilling screws or equivalent fastener secured <#>-inch o.c. along the panel side laps		
<table border="1"> <tr> <td data-bbox="430 1192 653 1219">W</td> <td data-bbox="653 1192 1894 1219">0.75" O.D. flat washer used with indicated fastener</td> </tr> </table>	W	0.75" O.D. flat washer used with indicated fastener	
W	0.75" O.D. flat washer used with indicated fastener		
<table border="1"> <tr> <td data-bbox="430 1226 653 1294">Wood Deck</td> <td data-bbox="653 1226 1894 1294">                     APA Span-Rated sheathing. The following nomenclature is used to further describe the As Tested condition.                 </td> </tr> </table>	Wood Deck	APA Span-Rated sheathing. The following nomenclature is used to further describe the As Tested condition.	
Wood Deck	APA Span-Rated sheathing. The following nomenclature is used to further describe the As Tested condition.		
<table border="1"> <tr> <td data-bbox="430 1300 653 1328">T&lt;#&gt;P</td> <td data-bbox="653 1300 1894 1328">Min. &lt;#&gt;-inch thickness of the plywood</td> </tr> </table>	T<#>P	Min. <#>-inch thickness of the plywood	
T<#>P	Min. <#>-inch thickness of the plywood		
<table border="1"> <tr> <td data-bbox="430 1334 653 1362">T&lt;#&gt;O</td> <td data-bbox="653 1334 1894 1362">Min. &lt;#&gt;-inch thickness of the OSB</td> </tr> </table>	T<#>O	Min. <#>-inch thickness of the OSB	
T<#>O	Min. <#>-inch thickness of the OSB		
<table border="1"> <tr> <td data-bbox="430 1369 653 1396">L&lt;#&gt;</td> <td data-bbox="653 1369 1894 1396">Max. span of &lt;#&gt; inches</td> </tr> </table>	L<#>	Max. span of <#> inches	
L<#>	Max. span of <#> inches		
<table border="1"> <tr> <td data-bbox="430 1403 653 1409">N&lt;#1&gt;/&lt;#2&gt;</td> <td data-bbox="653 1403 1894 1409">Min. 0.113" diameter x 2-3/8" ring shank nails spaced &lt;#1&gt;-inch o.c. at all intermediate supports and spaced &lt;#2&gt; at the perimeter of each board</td> </tr> </table>	N<#1>/<#2>	Min. 0.113" diameter x 2-3/8" ring shank nails spaced <#1>-inch o.c. at all intermediate supports and spaced <#2> at the perimeter of each board	
N<#1>/<#2>	Min. 0.113" diameter x 2-3/8" ring shank nails spaced <#1>-inch o.c. at all intermediate supports and spaced <#2> at the perimeter of each board		

Name	Definition
DensDeck	Min. 0.25" Georgia-Pacific DensDeck
DensDeck Prime	Min. 0.25" Georgia-Pacific DensDeck Prime
Insulation Adhesive	I.S.O. Twin Pack Insulation Adhesive, I.S.O. Stick Insulation Adhesive, or I.S.O. Fix II Adhesive
Insulation Adhesive II	I.S.O. Twin Pack Insulation Adhesive, I.S.O. Stick Insulation Adhesive, I.S.O. Fix II Adhesive, or Elevate I.S.O. Spray R
LWIC	Poured-in-place Cellular Lightweight Concrete with encapsulated insulation board
MCRF	Minimum Characteristic Resistance Force as determined by TAS 105 for the named fastener in the selected assembly
MDP	Maximum Design Pressure
Preliminarily Secured	Fastened at minimum rate of 5 per 4 ft x 8 ft board or 4 per 4 ft x 4 ft board.
SECUROCK	Min. 0.25" USG SECUROCK Gypsum-Fiber Roof Board
V-Force	One ply of Elevate V-Force Vapor Barrier Membrane. Non-metal substrates must be primed with Elevate SA Solvent-Based (SB) Primer, SA LVOC Primer or SA Water-Based (WB) Primer
XR Stick Membrane Adhesive	Adhered 12" o.c. in 3/4"-1" wide ribbons unless otherwise stated
I.S.O. Stick, I.S.O. Fix II, or I.S.O. Spray R	Adhered 12" o.c. in 3/4"-1" wide ribbons unless otherwise stated
I.S.O. Twin Pack Insulation Adhesive	Adhered 12" o.c. in 1/2" – 3/4" wide ribbons unless otherwise stated
Membrane Adhesive	Water Based Bonding Adhesive P adhered at a rate of 100-120 ft <sup>2</sup> /gal., or UltraPly Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 Adhered at a rate of 45-60 ft <sup>2</sup> /gal. unless otherwise stated
XR Membrane Adhesive	XR Stick Membrane Adhesive or I.S.O. Spray R
XR Membrane Adhesive II	XR Stick Membrane Adhesive, XR Bonding Adhesive, or I.S.O. Spray R, Hot asphalt, or PermaMop
InvisiWeld	Elevate UltraPly InvisiWeld Plates or InvisiWeld S Plates with Heavy Duty Fasteners or Concrete Drive fasteners (concrete decks only)
InvisiWeld S	Elevate UltraPly InvisiWeld S Plates with SFS Intec Dekfast #15 HS, Elevate Heavy Duty Fasteners or Elevate Concrete Drive fasteners (concrete decks only)
ISO	One or more layers of GenFlex ISO Insulation or Elevate ISO 95+ GL
ISO HD	One or more layers of GenFlex HD ISO or Elevate ISOGARD HD
ISO HD-C	One or more layers of GenFlex HD Composite ISO or Elevate ISOGARD HD Composite
PermaMop	Owens Corning PermaMop Asphalt

Name	Definition
HA	ASTM D 312, Type IV asphalt
UltraPly TPO	One ply of any one of the following products: 45-mil thick, 60-mil thick, or 80-mil thick UltraPly TPO
UltraPly TPO SA	One ply of any one of the following products: 45-mil thick or 60-mil thick UltraPly TPO SA
UltraPly TPO XR	One ply of any one of the following products: UltraPly TPO XR 100, UltraPly TPO XR 115 or UltraPly XR 135

**Insulation Note:** GenFlex ISO Insulation is equivalent to ISO 95+ GL, GenFlex HD ISO is equivalent to ISOGARD HD, GenFlex HD ISO Composite is equivalent to ISOGARD HD Composite, and Coated Glass Facer is equivalent to RESISTA

**Membrane Note:** GenFlex EZ TPO is equivalent to UltraPly TPO, UltraPly TPO XR 100 is equivalent to GenFlex EZ Fleece Backed TPO (45-mil), UltraPly TPO XR 115 is equivalent to GenFlex EZ Fleece Backed TPO (60-mil), and UltraPly TPO SA is equivalent to EZ TPO Peel and Stick HW, UltraPly TPO XR 135 is equivalent to GenFlex EZ Fleece Backed TPO (80-mil)

Table	System	Deck	Description
Table 1	S-A1 to S-A5	Steel	STEEL DECK, BONDED INSULATION, BONDED ROOF COVER
Table 2	S-B2 to S-B11	Steel	STEEL DECK, MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER
Table 3	S-C4 to S-C39	Steel	STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER
Table 4	S-CD3 to S-CD8	Steel	STEEL DECK, LOOSE LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, MECHANICALLY ATTACHED ROOF COVER
Table 5	LWC-D1 to LWC-D2	Lightweight Concrete	LIGHTWEIGHT CONCRETE DECK, PRELIMINARILY SECURED INSULATION, MECHANICALLY ATTACHED ROOF COVER
Table 6	S-D3 to S-D21	Steel	STEEL DECK, PRELIMINARILY SECURED INSULATION, MECHANICALLY ATTACHED ROOF COVER
Table 7	LWC-E1 to LWC-E15	Lightweight Concrete	LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, MECHANICALLY ATTACHED ROOF COVER
Table 8	LWC-F1 to LWC-F13	Lightweight Concrete	LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, ROOF COVER

**Limitations and Installation:**

<b>TABLE 1: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (Tear-Off) or RECOVER STEEL DECK, BONDED INSULATION, BONDED ROOF COVER</b>							
<b>Assembly No.</b>	<b>Substrate</b>	<b>Vapor/Thermal Barrier</b>	<b>Base Insulation Layer (s)</b>		<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
			<b>Type</b>	<b>Attach</b>	<b>Membrane</b>	<b>Attach</b>	
<b>S-A1</b>	Steel (G33, L5)	<b>(Optional)</b> V-Force, Self-adhered	Min. 1.5" ISO or RESISTA	I.S.O. Stick, I.S.O. Twin Pack, or I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	<b>-45.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	
<b>S-A2</b>	Steel (G33, L5)	Min. 0.5" DensDeck Prime adhered with I.S.O. Stick or I.S.O. Spray R, followed by BASEGARD SA self-adhered	Min. 0.5" ISO or RESISTA	HA, at a rate of 20-40 lbs/sq.	UltraPly TPO	Membrane Adhesive	<b>-45.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	
<b>S-A3</b>	Steel (G33, L5)	V-Force, Self-adhered	Min. 0.5" ISO or RESISTA followed by Cover Board II	I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	<b>-45.0</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-A4</b>	Steel (G33, L6, P, S24)	V-Force, Self-adhered	Min. 2" ISO or RESISTA	I.S.O. Twin Pack or I.S.O. Spray R, 6" o.c.	UltraPly TPO	Membrane Adhesive	<b>-60.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	
<b>S-A5</b>	Steel (G33, L6, P, S24)	None	Min. 2" ISO or RESISTA	I.S.O. Twin Pack or I.S.O. Spray R, 6" o.c.	UltraPly TPO	Membrane Adhesive	<b>-75.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

TABLE 2: ELEVATE ULTRAPLY TPO AND GENFLEX TPO – NEW CONSTRUCTION or REROOF (Tear-Off) or RECOVER STEEL DECK, MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER								
Assembly No.	Deck	Base Insulation		Top Insulation Layer (s)		Roof Cover		Design Pressure (psf)
		Type	Attach	Type	Fastener	Membrane	Attachment	
S-B2	Steel (G33)	Min. 0.5" DensDeck Prime (primed with SA Water-Based (WB) Primer	AP Fasteners & Plates; Fastener Density: 1:2.67 ft <sup>2</sup>	V-Force, self-adhered followed by Min. 1.5" ISO or RESISTA	I.S.O. Stick or I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	-45.0
						UltraPly TPO XR	XR Membrane Adhesive	
						UltraPly TPO SA	Self-adhered	
S-B3	Steel (G33)	DensDeck Prime primed with SA Solvent-Based (SB) primer	AP Fasteners & Plates. Fastener Density: 1:4 ft <sup>2</sup>	V-Force self-adhered followed by min. 1.5" ISO or tapered ISO followed by <b>(Optional)</b> min. 1.5" ISO, 0.5" ISO HD or DensDeck Prime	I.S.O. Stick or I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	-45.0
						UltraPly TPO XR	XR Membrane Adhesive	
						UltraPly TPO SA	Self-adhered	
S-B4	Steel (G33, F1, L6, S24)	Min. 0.5" ISO or RESISTA	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	Min. 1.5" ISO HD-C	I.S.O. Stick	UltraPly TPO	UltraPly Bonding Adhesive	-60.0
S-B5	Steel (G33, P, L6, S24)	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1.78 ft <sup>2</sup>	Min. 0.5" ISO or RESISTA followed by min. 0.5" ISO HD	I.S.O. Twin Pack or I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	-60.0
						UltraPly TPO XR	XR Membrane Adhesive	
						UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

TABLE 2: ELEVATE ULTRAPLY TPO AND GENFLEX TPO – NEW CONSTRUCTION or REROOF (Tear-Off) or RECOVER STEEL DECK, MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER								
Assembly No.	Deck	Base Insulation		Top Insulation Layer (s)		Roof Cover		Design Pressure (psf)
		Type	Attach	Type	Fastener	Membrane	Attachment	
S-B6	Steel (G33, L6, P, S24)	Min. 2" ISO or RESISTA	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	<b>Middle Insulation (Optional):</b> Min. 0.5" ISO or RESISTA followed by <b>Top Insulation:</b> Min. 0.5" ISO HD	I.S.O. Twin Pack Adhesive, 6" o.c., or I.S.O. Stick (not with ISO HD), I.S.O. Spray R, or I.S.O. Fix II (not with ISO HD), 12" o.c.	UltraPly TPO SA	Self-adhered	<b>-67.5</b>
						UltraPly TPO	Membrane Adhesive	
						UltraPly TPO XR	XR Membrane Adhesive	
S-B7	Steel (G33, L6, P, S24)	Min. 2" ISO or RESISTA	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	SECUROCK	I.S.O. Stick or I.S.O. Spray R, 6" o.c.	UltraPly TPO	Membrane Adhesive	<b>-67.5</b>
						UltraPly TPO XR	XR Membrane Adhesive II	
						UltraPly TPO SA	Self-adhered	
S-B8	Steel (G33, L6, P, S24)	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1.78 ft <sup>2</sup>	Min. 0.5" ISO HD	Insulation Adhesive II	UltraPly TPO	Membrane Adhesive	<b>-67.5</b>
						UltraPly TPO XR	XR Membrane Adhesive	
						UltraPly TPO SA	Self-adhered	
S-B9	Steel (G33, L6, F1, S24) (new only)	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1.6 ft <sup>2</sup>	Min. 0.5" ISO HD	Insulation Adhesive II (6" o.c.)	UltraPly TPO	Membrane Adhesive	<b>-82.5</b>
						UltraPly TPO XR	XR Membrane Adhesive	
						UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

<b>TABLE 2: ELEVATE ULTRAPLY TPO AND GENFLEX TPO – NEW CONSTRUCTION or REROOF (Tear-Off) or RECOVER STEEL DECK, MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER</b>								
<b>Assembly No.</b>	<b>Deck</b>	<b>Base Insulation</b>		<b>Top Insulation Layer (s)</b>		<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
		<b>Type</b>	<b>Attach</b>	<b>Type</b>	<b>Fastener</b>	<b>Membrane</b>	<b>Attachment</b>	
<b>S-B10</b>	Steel (G33, L6, F1, S24) (new only)	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1 ft <sup>2</sup>	0.5" DensDeck Prime or SECUROCK	I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	<b>-82.5</b>
						UltraPly TPO XR	XR Membrane Adhesive II	
						UltraPly TPO SA	Self-adhered	
<b>S-B11</b>	Steel (G80, L6, F1, S24) (new only)	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1 ft <sup>2</sup>	0.5" DensDeck Prime or SECUROCK	I.S.O. Spray R	UltraPly TPO	Membrane Adhesive	<b>-97.5</b>
						UltraPly TPO XR	XR Membrane Adhesive II	
						UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
S-C4	Steel (G33, L6)	<b>Top Insulation (Optional):</b> 4-6 mil thick polyethylene air barrier with Min. 2" wide laps sealed with duct tape or DensDeck primed with V-Force SB Primer followed by <b>Middle Insulation:</b> Min. 1.5" ISO (Flat or Tapered), RESISTA (Flat or Tapered), or ISO HD-C	Min. 0.5" SECUROCK	AP Fasteners & Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	-45.0
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
S-C5	Steel (G33)	Min. 0.5" ISO or RESISTA	Min. 0.5" DensDeck Prime or SECUROCK	AP Fasteners & Plates; Fastener Density: 1:2.67 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	-45.0
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
S-C6	Steel (G33)	Min. 0.5" ISO or RESISTA	Min. 0.5" SECUROCK	AP Fasteners & Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	-45.0
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
S-C7	Steel (G33, L6, P, S24)	Min. 1" ISO or RESISTA	SECUROCK	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	-45.0
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
S-C8	Steel (G33, L6, P, S24)	None	Min. 2" ISO or RESISTA or Min. 1/2" DensDeck Prime or SECUROCK	AP Fasteners & Plates; Fastener Density: 1:2.67 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-45.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	
S-C9	Steel (G33)	Min. 1" ISO or RESISTA	Min. 0.5" SECUROCK	AP Fasteners and Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-45</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive II	
S-C10	Steel (G33, L6, P, S24)	Min. 0.5" ISO, RESISTA, or 1.5" ISO HD-C	<b>(Optional)</b> Cover Board	InvisiWeld; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-45.0</b>
S-C11	Steel (G33)	0.5" ISO or RESISTA	SECUROCK	HD Fasteners & Insulation Plates; fastener density: 1:3.2 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-45</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive II	
S-C12	Steel (G33, L6,F1, S30) (new or existing)	None	Min. 1.5" ISO or RESISTA	InvisiWeld S; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld S plates	<b>-45</b>
S-C13	Steel (G33, L5) (new or existing)	Min. 1.5" ISO or RESISTA	Min. 0.5" ISO HD or DensDeck Prime	InvisiWeld; Fastener Density: 1:5.33 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-45</b>

**Limitations and Installation:**

<b>TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER</b>							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
<b>S-C14</b>	Steel (G80, L7, F2, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1" ISO or RESISTA, Cover Board II, or min. 1.5" ISO HD-C	InvisiWeld: fastened 12" o.c. in rows 72" o.c.	Min. 60 mil UltraPly TPO	Induction welded to InvisiWeld plates	<b>-45</b>
<b>S-C15</b>	Steel (G33, L6, F, S24)	None	Min. 0.5" ISO or RESISTA	AP Fasteners & Plates; Fastener Density: 1:1.6 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-52.5</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive	
<b>S-C16</b>	Steel (G33, L6, F, S24)	SECUROCK <b>(Optional)</b> followed by V-Force, Self-adhered followed by <b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 2.5" ISO or RESISTA	InvisiWeld; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-52.5</b>
<b>S-C17</b>	Steel (G33, L6, P, S12)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 0.5" DensDeck Prime	HD Fasteners & Insulation Plates. Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-52.5</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-C18</b>	Steel (G33, L6, F1, S30) (New or Existing)	Min. 1.5" ISO or RESISTA	Min. 0.5" ISO HD or DensDeck Prime	InvisiWeld; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-60.0</b>
<b>S-C19</b>	Steel (G33, L6, P, S12, W)	None	Min. 1.5" ISO or RESISTA, or Min 1/2" DensDeck Prime or SECUROCK	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-60.0</b>
					UltraPly TPO XR	XR Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	

**Limitations and Installation:**

<b>TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER</b>							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
<b>S-C20</b>	Steel (G33, L6, F, S24)	Min. 0.5" ISO or RESISTA	Min. 0.5" SECUROCK	2-1/4" AP Fasteners and Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-60.0</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive II	
<b>S-C21</b>	Steel (G33, L6, P, S24)	Min. 0.5" ISO or RESISTA	Min. 0.5" SECUROCK	AP Fasteners & Plates; Fastener Density: 1:2.13 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-60.0</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-C22</b>	Steel (G80, L7, F2, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1" ISO or RESISTA, Cover Board II, or min. 1.5" ISO HD-C	InvisiWeld; Fastener Density: 1:4 ft <sup>2</sup>	Min. 60 mil UltraPly TPO	Induction welded to InvisiWeld plates	<b>-60.0</b>
<b>S-C23</b>	Steel (G33, L6, HXE1, HS24)	None	Min. 1" ISO	InvisiWeld; Fastened 6" o.c. in rows spaced 144" o.c.	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-60.0</b>
<b>S-C24</b>	Steel (G33, L5)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 0.5" SECUROCK	AP Fasteners & Plates. Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-62.5</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-C25</b>	Steel (G33, L6, HXH1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 2" ISO or RESISTA	InvisiWeld; Fastener Density: 1:2.67 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-67.5</b>
<b>S-C26</b>	Steel (G33, L6, F1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1.5" ISO HD-C	AP Fasteners & Plates. Fastener Density: 1:2.13 ft <sup>2</sup>	UltraPly TPO	UltraPly Bonding Adhesive	<b>-67.5</b>

**Limitations and Installation:**

<b>TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER</b>							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
<b>S-C27</b>	Steel (G33, L6, P, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	SECUROCK or min. 0.5" DensDeck Prime	AP Fasteners & Plates. Fastener Density: 1:1.6 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-67.5</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-C28</b>	Steel (G33, L6, F1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1.5" ISO HD-C	AP Fasteners & Plates. Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO	UltraPly Bonding Adhesive	<b>-75</b>
<b>S-C29</b>	Steel (G33, L6, P, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 0.5" ISO HD, min. 1" ISO or RESISTA, Cover Board II or min. 1.5" ISO HD-C	InvisiWeld; Fastener Density: 1:2.67 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-75.0</b>
<b>S-C30</b>	Steel (G33, L6, F1, S24) (New only)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 2" ISO or RESISTA	AP Fasteners & Plates. Fastener Density: 1:1.6 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-75.0</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive	
<b>S-C31</b>	Steel (G33, L6, F1, S30) (New or Existing)	None	Min. 1.5" ISO or RESISTA	InvisiWeld S; Fastener Density: 1:3.2 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld S plates	<b>-75.0</b>
<b>S-C32</b>	Steel (G33, L6, F1, S30) (New or Existing)	Min. 1.5" ISO or RESISTA	Min. 0.5" ISO HD or DensDeck Prime	InvisiWeld; Fastener Density: 1:2.7 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-75.0</b>

**Limitations and Installation:**

TABLE 3: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER STEEL DECK, LOOSE-LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, BONDED ROOF COVER							
Assembly No.	Substrate	Base Insulation/Vapor Barrier Layer (s)	Top Insulation Layer(s)		Roof Cover		Design Pressure (psf)
			Type	Attach	Membrane	Attach	
<b>S-C35</b>	Steel (G33, L6, P, S24)	Min. 0.5" ISO or RESISTA	Min. 0.5" SECUROCK	AP Fasteners & Plates; Fastener Density: 1:1.78 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-82.5</b>
					UltraPly TPO XR	XR Membrane Adhesive II	
					UltraPly TPO SA	Self-adhered	
<b>S-C36</b>	Steel (G33, L6, HXE1, HS24)	None	Min. 1" ISO	InvisiWeld; Fastened 6" o.c. in rows spaced 72" o.c.	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-82.5</b>
<b>S-C37</b>	Steel (G80, L6)	None	Min. 2" ISO, RESISTA, or Cover Board	HD Fasteners & Insulation Plates; Fastener Density: 1:1 ft <sup>2</sup>	UltraPly TPO	Membrane Adhesive	<b>-90.0</b>
					UltraPly TPO XR	XR Stick Membrane Adhesive	
					UltraPly TPO SA	Self-adhered	
<b>S-C38</b>	Steel (G33, L6, F1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1.5" ISO or RESISTA	AP Fasteners & Plates; Fastener Density: 1:1.33 ft <sup>2</sup>	UltraPly TPO SA	Self-adhered	<b>-90.0</b>
					UltraPly TPO	Membrane Adhesive	
					UltraPly TPO XR	XR Membrane Adhesive	
<b>S-C39</b>	Steel (G33, L6, F2, S12)	Min. 1.5" ISO or RESISTA	Min. 0.5" ISO HD or DensDeck Prime	InvisiWeld; Fastener Density: 1:2 ft <sup>2</sup>	UltraPly TPO	Induction welded to InvisiWeld plates	<b>-105</b>

**Limitations and Installation:**

<b>TABLE 4: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (TEAR-OFF)</b>							
<b>STEEL DECK, LOOSE LAID BASE INSULATION, MECHANICALLY ATTACHED TOP INSULATION, MECHANICALLY ATTACHED ROOF COVER</b>							
<b>Assembly No.</b>	<b>Deck</b>	<b>Base Insulation Layer/Vapor Barrier (s)</b>	<b>Top Insulation Layer (s)</b>		<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
			<b>Type</b>	<b>Attachment</b>	<b>Membrane</b>	<b>Fasteners</b>	
<b>S-CD3</b>	Steel (G80, L6, F, S24)	V-Force Self-adhered followed by <b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 0.5" ISO, min. 0.5" RESISTA, or min. 1.5" ISO HD-C	HD Fasteners & Insulation Plates; Fastener Density: 1:8 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 114" o.c.	<b>-45.0</b>
<b>S-CD4</b>	Steel (G33, L6, F, S24)	V-Force (Self-adhered) followed by <b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 3" ISO, RESISTA, ISO HD-C	HD Fasteners & Insulation Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 114" o.c.	<b>-45.0</b>
<b>S-CD5</b>	Steel (G33, L6)	DensDeck Prime loose-laid followed by V-Force (Self-adhered)	Min. 2" ISO, RESISTA or min. 1.5" ISO HD-C	AP Fasteners & Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 114" o.c.	<b>-45.0</b>
<b>S-CD6</b>	Steel (18 ga. G50, L6, F, S24)	V-Force self-adhered followed by Min. 1.5" ISO or RESISTA	Min. 0.5" ISO, min. 0.5" RESISTA, min. 1.5" ISO HD-C	HD Fasteners & Insulation Plates; Fastener Density: 1:5.33 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 142" o.c.	<b>-52.5</b>
<b>S-CD7</b>	Steel (G33, L6, F, S24)	SECUROCK followed by V-Force (Self-adhered) followed by <b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 3" ISO or RESISTA	HD Fasteners & Insulation Plates; Fastener Density: 1:4 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 114" o.c.	<b>-52.5</b>
<b>S-CD8</b>	Steel (G80, L6, F, S24)	Two layers of V-Force (Self-adhered) followed by <b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 3" ISO, RESISTA, ISO HD-C	HD Fasteners & Insulation Plates; Fastener Density: 1:5.33 ft <sup>2</sup>	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 142" o.c.	<b>-82.5</b>

**Limitations and Installation:**

<b>TABLE 5 : ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (TEAR-OFF) or RECOVER LIGHTWEIGHT CONCRETE DECK, PRELIMINARILY SECURED INSULATION, MECHANICALLY ATTACHED ROOF COVER</b>								
<b>Assembly No.</b>	<b>Deck</b>	<b>Lightweight Concrete</b>	<b>Existing Roof</b>	<b>Insulation Layer(s)</b>		<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
				<b>Type</b>	<b>Attachment</b>	<b>Membrane</b>	<b>Fasteners</b>	
<b>LWC-D1</b>	Steel (G33, L5, P, S12)	Min. 1/4" slurry coat of LWIC followed by 1" EPS board and a 2" top coat	Modified Bitumen Roofing	Min. 0.5" ISO or RESISTA	Preliminarily Secured	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114" o.c.	<b>-45.0</b>
<b>LWC-D2</b>	Steel (G33, L5, P, S12)	Min. 1/4" slurry coat of LWIC followed by 1" EPS board and a 2" top coat	Modified Bitumen Roofing	Min. 0.5" ISO, min. 0.25" DensDeck Prime or SECUROCK, min. 0.5" ISO HD, min. 2" ISO HD-C or Min. 1" RESISTA	Preliminarily Secured	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114" o.c.	<b>-52.5</b>

**Limitations and Installation:**

<b>TABLE 6: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (TEAR-OFF) OR RECOVER STEEL DECK, PRELIMINARILY SECURED INSULATION, MECHANICALLY ATTACHED ROOF COVER</b>						
<b>Assembly No.</b>	<b>Deck</b>	<b>Base Insulation Layer/Vapor Barrier (s)</b>	<b>Top Insulation Layer (s)</b>	<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
				<b>Membrane</b>	<b>Fasteners</b>	
<b>S-D3</b>	Steel (G40, L6, P)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 1" ISO, RESISTA, or 1.5" ISO HD-C or Cover Board	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 90" o.c.	<b>-45.0</b>
<b>S-D4</b>	Steel (G80, L6, F1, S24) (new)	Min. 1.5" ISO or RESISTA or ISO HD-C	<b>(Optional)</b> Cover Board	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 114" o.c.	<b>-45.0</b>
				UltraPly TPO	HD Fasteners & Plates; Attached in-lap 12" o.c., side laps spaced 90" o.c.	
<b>S-D5</b>	Steel (G33, L6, F1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 0.5" ISO, RESISTA, or Min. 1.5" ISO HD-C, or Cover Board II	Min. 60-mil UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 90" o.c.	<b>-52.5</b>
<b>S-D6</b>	Steel (G33, L6, P, S24)	Min. 0.5" ISO, RESISTA, or 1.5" ISO HD-C	<b>(Optional)</b> Cover Board	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 90" o.c.	<b>-52.5</b>
<b>S-D7</b>	Steel (G80, F1, L6, S24) (New)	None	Min. 1.5" ISO, RESISTA, or ISO HD-C, or Min. 0.5" Cover Board II	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 142" o.c.	<b>-52.5</b>
<b>S-D8</b>	Steel (G33, L6, HXH1, HS24)	Min. 0.5" ISO or min. 1" RESISTA or min. 2" ISO HD-C	<b>(Optional)</b> Cover Board	Min. 60 mil UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 142" o.c.	<b>-52.5</b>
<b>S-D9</b>	Steel (G33, L6, HXH1, S24)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Min. 2" ISO or RESISTA	Min. 60-mil UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 89" o.c.	<b>-60.0</b>
<b>S-D10</b>	Steel (G33, L6, HXH1, HS24)	Min. 0.5" ISO or min. 1" RESISTA or min. 2" ISO HD-C	<b>(Optional)</b> Cover Board	Min. 60 mil UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114 o.c.	<b>-60.0</b>

**Limitations and Installation:**

<b>TABLE 6: ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (TEAR-OFF) OR RECOVER STEEL DECK, PRELIMINARILY SECURED INSULATION, MECHANICALLY ATTACHED ROOF COVER</b>						
<b>Assembly No.</b>	<b>Deck</b>	<b>Base Insulation Layer/Vapor Barrier (s)</b>	<b>Top Insulation Layer (s)</b>	<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
				<b>Membrane</b>	<b>Fasteners</b>	
<b>S-D11</b>	Steel (20 ga. G80, L6, P, S12, W)	None	Min. 0.5" ISO, Min. 1" RESISTA, or Min. 2" ISO HD-C followed by <b>(Optional)</b> Cover Board	Min. 60-mil UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114 o.c.	<b>-60.0</b>
<b>S-D12</b>	Steel (G80, L6, P, S24)	Min. 0.5" ISO, RESISTA, or 1.5" ISO HD-C	<b>(Optional)</b> Cover Board	UltraPly TPO	HD Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 89" o.c.	<b>-60.0</b>
<b>S-D13</b>	Steel (G33, F1, L6, S24) (New)	None	Min. 1.5" ISO or ISO HD-C	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 142" o.c.	<b>-60.0</b>
<b>S-D14</b>	Steel (18 ga. G50, L6, P)	<b>(Optional)</b> Min. 0.5" ISO or RESISTA	Cover Board or min. 1" ISO, RESISTA, or 1.5" ISO HD-C	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114" o.c.	<b>-67.5</b>
<b>S-D15</b>	Steel (G33, F1, L6, S24) (New)	None	Min. 1.5" ISO or ISO HD-C	UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114" o.c.	<b>-67.5</b>
<b>S-D16</b>	Steel (G33, L6)	Min. 1" ISO or RESISTA	Cover Board II or min. 1" RESISTA or Min. 1.5" ISO, ISO HD-C	Min. 60-mil UltraPly TPO	HD Plus Fasteners & Plates; Attached in-lap 6" o.c., side laps spaced 114" o.c.	<b>-67.5</b>
<b>S-D17</b>	Steel (G80, F2, L6, S24) (New)	None	Min. 1.5" ISO, RESISTA, or ISO HD-C, or Min. 0.5" Cover Board II	UltraPly TPO	HD Fasteners and Polymer Batten Strips centered in-lap and fastened 6" o.c.; Fastener rows 68" o.c.; Min. 5" wide heat weld encapsulating plates and fasteners	<b>-82.5</b>

TABLE 6 (CONTINUED): ELEVATE ULTRAPLY TPO AND GENFLEX EZ TPO - NEW CONSTRUCTION or REROOF (Tear-Off) STEEL DECK, LOOSE-LAID INSULATION, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER							
Assembly No.	Substrate	Base Insulation Layer (s)	Base Sheet		Roof Cover		Design Pressure (psf)
			Type	Attach	Type	Attach	
<b>S-D18</b>	Steel (G80, F2, L6, S24) (New)	None	Min. 1.5" ISO, RESISTA, or ISO HD-C, or Min. 0.5" Cover Board II	UltraPly TPO	HD Plus Fasteners and Polymer Batten Strips centered in-lap and fastened 6" o.c.; Intermediate row in field of sheet with fasteners 6" o.c.; Fastener rows spaced 71" o.c.; Min. 5" wide heat weld encapsulating plates and fasteners in-lap;		<b>-135.0</b>
<b>S-D20</b>	Steel (G33)	Min. 0.5" ISO or RESISTA	MB Base, 2" side lap	AP Fasteners & Plates; fastened 12" o.c. at the lap and 12" o.c. in two staggered intermediate rows in the field of the row	UltraPly TPO XR	HA, at a rate of 25-30 lb/sq.	<b>-45.0</b>
<b>S-D21</b>	Steel (G33)	Min. 1" ISO or RESISTA	SBS Base, 3.4" side lap	AP Fasteners & Plates; fastened 12" o.c. at the lap and 12" o.c. in two staggered intermediate rows in the field of the row	UltraPly TPO XR	XR Stick Membrane Adhesive	<b>-45.0</b>

**Limitations and Installation:**

<b>TABLE 7: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, MECHANICALLY ATTACHED ROOF COVER</b>								
Assembly No.	Substrate	Lightweight Concrete	Existing Roof	Roof Cover				Design Pressure (psf)
				Base Sheet	Attachment	Membrane	Attachment	
<b>LWC-E1</b>	Steel (G33, L5, P, S12W) or Concrete (New or Existing)	Min. 1/4" slurry of Min. 220 psi Elastizell with Zell-Crete Fibers with 1" EPS board and a 2" topcoat	N/A	SBS Base or SBS Poly Base with Min. 3.5" wide side laps	1.7" LWC Base-Ply Fasteners attached 9" o.c. at the lap and 9" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	HA	<b>-45.0</b>
<b>LWC-E2</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of min. 380 psi, Celcore MF with Celcore HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Min. 60-mil UltraPly TPO	Attached in-lap 12" o.c. with HD Fasteners & Plates; Fastener rows 114" o.c.	N/A	N/A	<b>-45.0</b>
<b>LWC-E3</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of min. 380 psi, Celcore MF with Celcore HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Min. 60-mil UltraPly TPO	Attached in-lap 12" o.c. with HD Fasteners & Plates; Fastener rows 90" o.c.	N/A	N/A	<b>-45.0</b>
<b>LWC-E4</b>	Steel (G33, L5, P, S18)	Min. 1/4" slurry of min. 359 psi, Celcore MF with Celcore HS Rheology Lightweight Concrete with 1" EPS board and a 2" topcoat	N/A	SBS Poly Base	1.7" LWC Base-Ply Fasteners. Base Sheet Attachment: Max. Fastener Spacing: 7" o.c.; Max. Row Spacing: 7" o.c.; Min. # of Staggered Rows: 2	UltraPly TPO XR	I.S.O. Spray R	<b>-52.5</b>

**Limitations and Installation:**

<b>TABLE 7: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, MECHANICALLY ATTACHED ROOF COVER</b>								
<b>Assembly No.</b>	<b>Substrate</b>	<b>Lightweight Concrete</b>	<b>Existing Roof</b>	<b>Roof Cover</b>				<b>Design Pressure (psf)</b>
				<b>Base Sheet</b>	<b>Attachment</b>	<b>Membrane</b>	<b>Attachment</b>	
<b>LWC-E5</b>	Steel (G33, P, L5, S18) or Concrete (New or Existing)	Min. 1/4" slurry of Min. 300 psi Celcore MF with HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	SBS Base Min. 3.4" wide side laps	1.7" LWC Base Ply Fastener attached 9" o.c. at the lap and 9" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	I.S.O. Spray R	<b>-52.5</b>
<b>LWC-E6</b>	Steel (G33, PW, L6, S18) or Concrete (New or Existing)	Min. 1/4" slurry of Min. 420 psi Celcore MF with HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Channel Venting Base Min. 4" wide side laps	1.7" LWC Base Ply Fastener attached 7" o.c. at the lap and 7" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	I.S.O. Spray R	<b>-52.5</b>
<b>LWC-E7</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of min. 380 psi, Celcore MF with Celcore HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Min. 60-mil UltraPly TPO	Attached in-lap 6" o.c. with HD Fasteners & Plates; Fastener rows 90" o.c.	N/A	N/A	<b>-52.5</b>
<b>LWC-E8</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of min. 380 psi, Celcore MF with Celcore HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Min. 60-mil UltraPly TPO	Attached in-lap 6" o.c. with HD Fasteners & Plates; Fastener rows 142" o.c.	N/A	N/A	<b>-52.5</b>

**Limitations and Installation:**

<b>TABLE 7: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, MECHANICALLY ATTACHED ROOF COVER</b>								
<b>Assembly No.</b>	<b>Substrate</b>	<b>Lightweight Concrete</b>	<b>Existing Roof</b>	<b>Roof Cover</b>				<b>Design Pressure (psf)</b>
				<b>Base Sheet</b>	<b>Attachment</b>	<b>Membrane</b>	<b>Attachment</b>	
<b>LWC-E9</b>	Steel (G33, P, L5, S18) or Concrete (New or Existing)	Min. 1/4" slurry of Min. 300 psi Celcore MF with HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	SBS Poly Base Min. 3.4" wide side laps	1.8" Two Piece Impact Nail attached 9" o.c. at the lap and 9" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	I.S.O. Spray R	<b>-60</b>
<b>LWC-E10</b>	Steel (G33, P, L6, S18) or Concrete (New or Existing)	Min. 1/4" slurry of Min. 400 psi Celcore MF with HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	SBS Base Min. 3.4" wide side laps	1.7" LWC Base Ply Fastener attached 7" o.c. at the lap and 7" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	I.S.O. Spray R	<b>-67.5</b>
<b>LWC-E11</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of min. 380 psi, Celcore MF with Celcore HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Min. 60 mil UltraPly TPO (120" wide)	Attached in-lap 6" o.c. with HD Fasteners & Plates; Fastener rows 114" o.c.	N/A	N/A	<b>-67.5</b>
<b>LWC-E12</b>	Steel (G33, P, L6, S18) or Concrete	Min. 1/4" slurry of Min. 360 psi Celcore MF with HS Rheology and Celcore S-1 (steel deck only) with 1" EPS board and a 2" topcoat	N/A	Channel Venting Base Min. 3.4" wide side laps	1.8" Two Piece Impact Nail attached 7" o.c. at the lap and 7" o.c. in two equally spaced, staggered rows in the field of the roll	UltraPly TPO XR	I.S.O. Spray R	<b>-75.0</b>

**Limitations and Installation:**

<b>TABLE 7: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION, REROOF (Tear-Off) or RECOVER LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, MECHANICALLY ATTACHED ROOF COVER</b>								
Assembly No.	Substrate	Lightweight Concrete	Existing Roof	Roof Cover				Design Pressure (psf)
				Base Sheet	Attachment	Membrane	Attachment	
<b>LWC-E13</b>	Steel (G33, L5, P, S18)	Min. 1/4" slurry coat of min. 293 psi, Celcore MF with Celcore HS Rheology Lightweight Concrete with 1" EPS board and a 2" topcoat	SBS Modified Roofing	UltraPly TPO XR; 5" wide inverted strips of membrane are laid over substrate	Base strips fastened with HD Fasteners & Plates; Roof Cover Attachment: Max. Fastener Spacing: 6" o.c.; Max. Row Spacing: 72" o.c.	UltraPly TPO XR	I.S.O. Spray R	<b>-90.0</b>
<b>LWC-E14</b>	Steel (G33, L6, F, W, S12)	Min. 1/8" slurry coat of min. 300 psi, Celcore LWIC with 1" EPS board and a 2" topcoat. MCRF: 390 lbf	<b>(Optional)</b> Single-Ply Membrane	UltraPly TPO	Polymer Batten Strips and HD Fasteners. Cover strip heat welded 1.5" over battens. Roof Cover Attachment: Max. Fastener Spacing: 6" o.c.; Max. Row Spacing: 48" o.c.	N/A	N/A	<b>-97.5</b>
<b>LWC-E15</b>	Steel (G33, L6, F, W, S12)	Min. 1/8" slurry coat of min. 300 psi, Celcore LWIC with 1" EPS board and a 2" topcoat MCRF: 450 lbf	<b>(Optional)</b> Single-Ply Membrane	UltraPly TPO XR	Polymer Batten Strips and HD Fasteners. Cover strip heat welded 1.5" over battens. Roof Cover Attachment: Max. Fastener Spacing: 6" o.c.; Max. Row Spacing: 48" o.c.	N/A	N/A	<b>-112.5</b>

**Limitations and Installation:**

<b>TABLE 8: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (Tear-Off) LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER</b>						
<b>Assembly No.</b>	<b>Substrate</b>	<b>Vapor Barrier</b>	<b>Lightweight Concrete</b>	<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
				<b>Membrane</b>	<b>Attach</b>	
<b>LWC-F1</b>	Steel (G33, F1, L6, S12)	None	Min. 1/8" slurry coat of Min. 300 psi Elastizell with 1" EPS board and a 2" topcoat secured with HD Fasteners & Plates through-fastened to Steel Deck at a rate of one per 2 ft <sup>2</sup>	UltraPly TPO	UltraPly Bonding Adhesive or Single-Ply LVOC Bonding Adhesive	<b>-135.0</b>
<b>LWC-F2</b>	Steel or Concrete (New or Existing)	None	Min. 1/4" slurry coat of Min. 390 psi Celcore MF with HS Rheology over deck treated with Celcore S-1 (steel deck only) followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO XR	I.S.O. Spray R	<b>-135.0</b>
<b>LWC-F3</b>	Structural Concrete	None	Min. 1/8" slurry coat of min. 300 psi, Elastizell LWIC with 1" EPS board and a 2" top coat	UltraPly TPO XR	XR Stick Membrane Adhesive	<b>-136.0</b>
<b>LWC-F4</b>	Steel or Concrete (New or Existing)	None	Min. 1/4" slurry coat of Min. 390 psi Celcore MF with HS Rheology over deck treated with Celcore S-1 (steel deck only) followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO	UltraPly Bonding Adhesive	<b>-140.0</b>
<b>LWC-F5</b>	Structural Concrete	None	Min. 1/8" slurry coat of min. 300 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO XR	XR Stick Membrane Adhesive	<b>-144.5</b>
<b>LWC-F6</b>	Steel ASTM A 653 G90	None	Min. 1/4" slurry coat of min. 200 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO	Single-Ply LVOC Bonding Adhesive	<b>-152.5</b>
<b>LWC-F7</b>	CWF	None	Min. 1/4" slurry coat of min. 200 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO	UltraPly Bonding Adhesive	<b>-155.0</b>

**Limitations and Installation:**

<b>TABLE 8: ELEVATE ULTRAPLY AND GENFLEX EZ TPO – NEW CONSTRUCTION or REROOF (Tear-Off) LIGHTWEIGHT CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER</b>						
<b>Assembly No.</b>	<b>Substrate</b>	<b>Vapor Barrier</b>	<b>Lightweight Concrete</b>	<b>Roof Cover</b>		<b>Design Pressure (psf)</b>
				<b>Membrane</b>	<b>Attach</b>	
<b>LWC-F8</b>	Structural Concrete (New or Existing)	None	Min. 1/4" slurry coat of min. 200 psi, Elastizell LWIC with Zell-Crete Fibers with 1" EPS board and a 2" topcoat	UltraPly TPO	Single-Ply LVOC Bonding Adhesive	<b>-157.5</b>
<b>LWC-F9</b>	CWF	None	Min. 1/4" slurry coat of min. 200 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO XR	XR Stick Membrane Adhesive	<b>-160.0</b>
<b>LWC-F10</b>	Structural Concrete (New or Existing)	None	LWIC, min. 350 psi., composed with Celcore MF with Celcore HS Rheology Modifying Admixture applied in min. 1/8" slurry coat with 1" Holey board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO	UltraPly Bonding Adhesive	<b>-247.5</b>
<b>LWC-F11</b>	Structural Concrete	SBS Glass Base Torch, torch-applied	Min. 1/4" slurry coat of min. 300 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO XR	XR Stick Membrane Adhesive	<b>-350.0</b>
<b>LWC-F12</b>	Structural Concrete (New or Existing)	None	Concrete deck is primed with Celcore S-1. LWIC, min. 350 psi., composed with Celcore MF with Celcore HS Rheology Modifying Admixture applied in min. 1/4" slurry coat with 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO XR	I.S.O. Spray R	<b>-397.5</b>
<b>LWC-F13</b>	Structural Concrete	SBS Glass Base Torch, torch-applied	Min. 1/4" slurry coat of min. 300 psi, Celcore LWIC composed with MF with Celcore HS Rheology Modifying Admixture followed by 1" EPS board and a 2" topcoat. Celcore PVA curing compound is applied at 300 ft <sup>2</sup> /sq.	UltraPly TPO	UltraPly Bonding Adhesive	<b>-455.0</b>

**Note:** Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.