



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
  2. REFER TO EZT-LS-1 OR EZT-LS-2 FOR WELD WIDTH.
  3. INSTALL METAL WORK TO SMACNA RECOMMENDATIONS.
  4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (12.7 mm) FROM EDGE OF WOOD.
  5. INSTALL TPO COATED METAL WITH 1/8" (3.175 mm) TO 1/4" (6.35 mm) MAX. BETWEEN ADJOINING SECTIONS.
  6. **SEE EZT-C-06A FOR DETAILED INSTALLATION INSTRUCTIONS.**
  7. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-LS-14 FOR CUT EDGE SEALANT APPLICATION.
  8. MINIMUM 2" (50.8 mm) WELD REQUIRED IN ALL DIRECTIONS OUT FROM ALL BREAKS IN METAL FLASHING.

**WARRANTY MEMBRANE REQUIREMENTS:**  
**15-YEAR**  
 TPO - 45 MIL  
**20-YEAR**  
 TPO - 60 MIL

APPROPRIATE TPO MEMBRANE HEAT WELDED TO EZ TPO COATED METAL (SEE NOTE #3 AND #7)

6" (152.4 mm) WIDE (MIN.) STRIP OF APPROPRIATE TPO NON-REINFORCED FLASHING CENTERED OVER CORNER AND HEAT WELDED IN PLACE (SEE NOTE #2)

**OUTSIDE CORNER WITH TPO COATED METAL (WITH BRAKE)**

MATERIAL: EZ TPO ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:  
**04/16/2026**

DETAIL NO.  
**EZT-C-06**

GENFLEX: (800) 443-4272 www.genflex.com

NOT TO SCALE

