



**NOTE:**

1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
2. REMOVE ALL EXISTING FLASHING, LEAD, ETC. PIPE SURFACE MUST BE FREE OF ALL RUST, GREASE, INSULATION, ETC.
3. PIPE MUST BE ANCHORED TO ENSURE STABILITY.
4. PRE-MOLDED PIPE FLASHING MAY BE CUT TO HEIGHT, BUT NO LOWER THAN REINFORCING RING (NO WRINKLES OR FOLDS UNDER CLAMPING RING, FLANGE MUST BE FLAT).
5. APPLY TERMINATION CAULK BETWEEN PENETRATION AND PRE-MOLDED PIPE FLASHING PRIOR TO INSTALLATION OF CLAMPING RING.
6. PRE-MOLDED PIPE FLASHING FITS 1" (25.4 mm) - 6" (152.4 mm) PENETRATIONS SIZES.
7. DO NOT USE WHEN SERVICE LINE TEMP. EXCEEDS 160 °F (71.11 °C). REFER TO EZT-P-06 & EZT-P-07.
8. GENFAST FASTENER AND SEAM PLATE REQUIRE FOR MAS ONLY. IF FASTENER CANNOT BE INSTALLED AS ILLUSTRATED, REFER TO DETAILS EZT-P-15 & EZT-P-16
9. PIPE BOOT MUST NOT BE TWISTED, CUPPED OR CUT AND PATCHED FOR INSTALLATION OF PENETRATION.

**WARRANTY MEMBRANE REQUIREMENTS:**  
**15-YEAR**  
 TPO - 45 MIL  
**20-YEAR**  
 TPO - 60 MIL

	<b>PENETRATION WITH EZ TPO PEEL &amp; STICK PIPE FLASHING</b>		MAXIMUM WARRANTY: 20 Years	
	MATERIAL: EZ TPO	ACCEPTABLE SYSTEMS: ALL	ISSUE / REVISION DATE: <b>04/20/2026</b>	DETAIL NO. <b>EZT-P-03</b>
GENFLEX: (800) 443-4272 www.genflex.com			NOT TO SCALE	