

USE APPROPRIATE TERMINATION

HEAT RESISTANT TAPE (BY OTHERS) OVER EZ TPO COATED METAL SPLICE

APPROPRIATE EZ TPO COATED METAL (SEE NOTE #3)

BRAKE

6" (152 mm) WIDE (MIN.) STRIP OF EZ TPO FLASHING HEAT WELDED OVER METAL JOINT (DO NOT WELD TO TAPE)

8" (203 mm) WIDE (MIN.) STRIP OF EZ TPO HEAT WELDED OVER EZ FB TPO / EZ TPO COATED METAL BUTT JOINT (SEE NOTE #2)

WALL / CURB

APPROVED SUBSTRATE

DECK

WOOD NAILER (SEE NOTE #4)

EZ FLEECE BACKED TPO MEMBRANE BUTTED TO COATED METAL

WHEN ASPHALT IS USED, STOP ASPHALT APPLICATION SHORT OF WALL TO ENSURE WALL SUBSTRATE STAYS FREE OF ASPHALT

NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. REFER TO DETAIL EZT-FB-LS-01 OR EZT-FB-LS-03 FOR WELD WIDTH.
3. INSTALL METAL WORK TO SMACNA RECOMMENDATIONS.
4. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
5. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
6. INSTALL EZ TPO COATED METAL WITH 1/8" (3 mm) MIN. TO 1/4" (6 mm) MAX. BETWEEN ADJOINING SECTIONS.
7. SEE EZT-BT-09A & EZT-BT-09B FOR DETAILED INSTALLATION INSTRUCTIONS.
8. WHEN REINFORCEMENT OF MEMBRANE IS EXPOSED, REFER TO EZT-LS-14 FOR CUT EDGE SEALANT APPLICATION.

WARRANTY MEMBRANE REQUIREMENTS:

15-YEAR

TPO - 45 MIL

20-YEAR

TPO - 60 MIL



BASE TIE-IN WITH EZ TPO COATED METAL (WITH BRAKE) SPLICE

MATERIAL: EZ FLEECE BACKED TPO

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/20/2026

DETAIL NO.

EZT-FB-BT-06

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com