



NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. ALLOW 1/4" (6 mm) MAX. SPACE BETWEEN SECTIONS OF DRAIN BAR.
3. ROUND ALL METAL CORNERS AND PLACE BACK OF GUTTER STRAP 1/4" (6 mm) BELOW TOP OF WOOD NAILER.
4. DO NOT PRE-NAIL MEMBRANE TO THE FACE OF THE WOOD NAILER.
5. CONSTRUCT AND ANCHOR GUTTER IN ACCORDANCE WITH SMACNA RECOMMENDATIONS.
6. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
7. ON BALLASTED TPO ROOFS, DRAIN BAR HEIGHT MUST MEET OR EXCEED BALLAST OR PAVER HEIGHT (2" (51 mm) MIN. ABOVE ROOF SURFACE).
8. GENFLEX TERMINATION BAR AND STAINLESS STEEL FASTENERS MAY BE USED IN LIEU OF METAL DRAIN BAR FOR MECHANICALLY ATTACHED AND ADHERED SYSTEMS ONLY.
9. APPROPRIATE GENFLEX MEMBRANE ADHESIVE REQUIRED BETWEEN MEMBRANE AND INSULATION FOR ADHERED SYSTEMS.

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL



**EZ FLEECE BACKED TPO MEMBRANE ROOF EDGE
 GUTTER WITH METAL DRAIN BAR**

MATERIAL: EZ FLEECE BACKED TPO

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
 DATE:

04/20/2026

DETAIL NO.

EZT-FB-RE-03

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com