

HEAT RESISTANT TAPE
(BY OTHERS) OVER
EZ TPO COATED METAL
SPLICE

6" (152 MM) WIDE (MIN.) STRIP OF EZ TPO FLASHING
(NON-REINFORCED) HEAT WELDED OVER JOINT AND
DOWN FACE (DO NOT WELD OVER TAPE)

EZ TPO
COATED METAL
(SEE NOTE #3
AND #4)

APPROPRIATE INSULATION
SUBSTRATE

WALL

WOOD NAILER
(SEE NOTE #5)

EZ FLEECE BACKED TPO
MEMBRANE (SELVEDGE
EDGE) HEAT WELDED TO
EZ TPO COATED METAL
(DO NOT WELD OVER
TAPE)

CONTINUOUS
CLEAT (BY
OTHERS)

NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
2. REFER TO DETAIL EZT-FB-LS-01 OR EZT-FB-LS-02 FOR WELD WIDTH.
3. INSTALL METAL WORK TO SMACNA RECOMMENDATIONS.
4. INSTALL EZ TPO COATED METAL WITH 1/8" (3 mm) MIN. TO 1/4" (6 mm) MAX BETWEEN ADJOINING SECTIONS.
5. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
6. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
7. ON BALLASTED TPO ROOFS, GRAVEL STOP HEIGHT MUST MEET OR EXCEED BALLAST OR PAVER HEIGHT (2" (51 mm) MIN. ABOVE ROOF SURFACE).
8. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-LS-14 FOR CUT EDGE SEALANT APPLICATION.
9. SEE EZT-FB-RE-05A & EZT-FB-RE-05B FOR DETAILED INSTALLATION INSTRUCTIONS.

WARRANTY MEMBRANE REQUIREMENTS:

15-YEAR
TPO - 45 MIL
20-YEAR
TPO - 60 MIL



**ROOF EDGE WITH EZ TPO COATED METAL
(WITH EZ FB TPO MEMBRANE SELVEDGE EDGE)**

MATERIAL: EZ FLEECE BACKED TPO

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:

04/20/2026

DETAIL NO.

EZT-FB-RE-05

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com