



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
 2. REFER TO DETAIL EZT-PS-LS-01 FOR WELD WIDTH.
 3. REMOVE ALL EXISTING FLASHING, LEAD, ETC. PIPE SURFACE MUST BE FREE OF ALL RUST, GREASE, INSULATION, ETC.
 4. PIPE MUST BE ANCHORED TO ENSURE STABILITY.
 5. NO WRINKLES OR FOLDS UNDER CLAMPING RING.
 6. DO NOT USE WHEN SERVICE LINE TEMP. EXCEEDS 160 °F (71 °C). REFER TO EZT-P-07.
 7. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-PS-LS-04 FOR CUT EDGE SEALANT APPLICATION.
 8. REFER TO GENFLEX PDS SHEETS AND APPLICATION GUIDES FOR LIST OF COMPATIBLE SUBSTRATES WITH GENFLEX EZ TPO PEEL & STICK MEMBRANE



PENETRATION WITH GENFLEX NON-REINFORCED FLASHING

MATERIAL: EZ TPO P&S

ACCEPTABLE SYSTEMS: ADHERED

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/20/2026

DETAIL NO.

EZT-PS-P-03

NOT TO SCALE