



- NOTE:**
1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
 2. REFER TO DETAIL EZT-PS-LS-01 OR EZT-PS-LS-02 FOR WELD WIDTH.
 3. NAILING AND METAL COUNTER-FLASHING ARE NOT REQUIRED IF MEMBRANE IS RUN UP AND OVER CURB WALLS PRIOR TO INSTALLATION OF R.T.U.
 4. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE MOUNTED TIGHTLY TO UNDERSIDE OF MECHANICAL UNIT.
 5. MAXIMUM 10" (254 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENT).
 6. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-PS-LS-04 FOR CUT EDGE SEALANT APPLICATION.
 7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
 8. APPROPRIATE PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN GENFLEX EZ TPO PEEL & STICK IS USED FOR FLASHING.
 9. REFER TO GENFLEX PDS SHEETS AND APPLICATION GUIDES FOR LIST OF COMPATIBLE SUBSTRATES WITH GENFLEX EZ TPO PEEL & STICK MEMBRANE.
 10. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES

	TERMINATION AT R.T.U. WITH WELDED SPLICE AND COUNTER-FLASHING (UNIT FLANGE MOUNTED TO SUBSTRATE)		MAXIMUM WARRANTY: 20 Years		
	MATERIAL: EZ TPO P&S	ACCEPTABLE SYSTEMS: ADHERED	ISSUE / REVISION DATE: 04/20/2026	DETAIL NO. EZT-PS-T-07	
GENFLEX: (800) 443-4272 www.genflex.com				NOT TO SCALE	