



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
 2. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANTS REQUIRED. NOT INCLUDED AS PART OF THE GENFLEX WARRANTY.
 3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (0.81 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
 4. INSTALL GENFLEX TERMINATION BAR WITH 1/4" (6.35 mm) GAP BETWEEN ADJOINING SECTIONS.
 5. TERMINATION BAR MUST BE CUT AT INSIDE AND INSIDE CORNERS. DO NOT BEND AROUND CORNERS.
 6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25.4 mm) MAX. OF ALL SECTION ENDS.
 7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
 8. STANDARD 0.060" (1.52 mm) GENFLEX EZ TPO MEMBRANE CAN BE USED AS VERTICAL WALL FLASHING IN LIEU OF GENFLEX EZ TPO PEEL & STICK MEMBRANE. APPROPRIATE ADHESIVE MUST BE USED.
 9. APPROPRIATE PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN EZ TPO PEEL & STICK MEMBRANE IS USED FOR FLASHING.
 10. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES
 11. IF INTERMEDIATE ATTACHMENT IS REQUIRED, COMPLETE AS FOLLOWS:
 - UP TO 5' (1.52 m) WALL HEIGHT- NONE REQUIRED
 - 5' (1.52 m) - 10' (3.05 m) WALL HEIGHT - ONE ATTACHMENT AT 1/2 THE WALL HEIGHT
 - ABOVE 10' (3.05 m) - ONE ATTACHMENT EVERY 3' (0.91 m)



TERMINATION WITH SURFACE MOUNTED COUNTER-FLASHING AND TERMINATION BAR	
MATERIAL: EZ TPO P&S	ACCEPTABLE SYSTEMS: ADHERED

MAXIMUM WARRANTY: 20 Years	
ISSUE / REVISION DATE: 04/20/2026	DETAIL NO. EZT-PS-T-09
NOT TO SCALE	