



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
  2. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANTS REQUIRED. NOT INCLUDED AS PART OF THE HOLCIM WARRANTY.
  3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (0.81 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
  4. INSTALL GENFLEX TERMINATION BAR WITH 1/4" (6.35 mm) GAP BETWEEN ADJOINING SECTIONS.
  5. TERMINATION BAR MUST BE CUT AT INSIDE AND INSIDE CORNERS. DO NOT BEND AROUND CORNERS.
  6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25.4 mm) MAX. OF ALL SECTION ENDS.
  7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
  8. STANDARD 0.060" (1.52 mm) GENFLEX EZ TPO MEMBRANE CAN BE USED AS VERTICAL WALL FLASHING IN LIEU OF GENFLEX EZ TPO PEEL & STICK MEMBRANE. APPROPRIATE MEMBRANE ADHESIVE MUST BE USED.
  9. APPROVED PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN GENFLEX EZ TPO PEEL & STICK MEMBRANE IS USED FOR FLASHING.
  10. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES.
  11. IF INTERMEDIATE ATTACHMENT IS REQUIRED, COMPLETE AS FOLLOWS:
    - UP TO 5' (1.52 m) WALL HEIGHT- NONE REQUIRED
    - 5' (1.52 m) - 10' (3.05 m) WALL HEIGHT - ONE ATTACHMENT AT 1/2 THE WALL HEIGHT
    - ABOVE 10' (3.05 m) - ONE ATTACHMENT EVERY 3' (.091 m)



**TERMINATION WITH REGLET COUNTER-FLASHING AND TERMINATION BAR**

MATERIAL: EZ TPO P&S

ACCEPTABLE SYSTEMS: ADHERED

GENFLEX: (800) 443-4272 www.genflex.com

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/20/2026

NOT TO SCALE

DETAIL NO.

**EZT-PS-T-10**