



NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. NAILING AND METAL COUNTER-FLASHING ARE NOT REQUIRED IF MEMBRANE IS RUN UP AND OVER CURB WALLS PRIOR TO INSTALLATION OF R.T.U.
3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (0.81 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE MOUNTED TIGHTLY TO UNDERSIDE OF MECHANICAL UNIT.
4. MAXIMUM 10" (254 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENT).
5. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
6. REFER TO EZT-PS-BT-8 & EZT-PS-BT-9 FOR MEMBRANE SECUREMENT AT CORNERS.
7. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO EZT-P-LS-04 FOR CUT EDGE SEALANT APPLICATION.
8. APPROPRIATE PRIMER REQUIRED ON ALL VERTICAL SURFACES WHEN GENFLEX EZ TPO PEEL & STICK MEMBRANE IS USED FOR FLASHING.
9. REFER TO TPO APPLICATION GUIDE FOR ACCEPTABLE FLASHING SUBSTRATES.
10. REFER TO GENFLEX PDS SHEETS AND APPLICATION GUIDES FOR LIST OF COMPATIBLE SUBSTRATES WITH GENFLEX EZ TPO PEEL & STICK MEMBRANE.



**TERMINATION AT R.T.U WITH COUNTER-FLASHING
(UNIT FLANGE TO SUBSTRATE)**

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:
04/20/2026

DETAIL NO.
EZT-PS-T-14

MATERIAL: EZ TPO P&S

ACCEPTABLE SYSTEMS: ADHERED

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com