



NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
2. ALLOW 1/4" (6.35 mm) MAX. SPACE BETWEEN SECTIONS OF DRAIN BAR.
3. ROUND ALL METAL CORNERS AND PLACE BREAK OF GUTTER STRAP 1/4" (6.35 mm) BELOW TOP OF WOOD NAILER.
4. DO NOT PRE-NAIL MEMBRANE TO FACE OF THE WOOD NAILER.
5. CONSTRUCT AND ANCHOR GUTTER IN ACCORDANCE WITH SMACNA.
6. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
7. ON BALLASTED ROOFS, DRAIN BAR HEIGHT MUST MEET OR EXCEED BALLAST OR PAVER HEIGHT (2" (50.8 mm) MIN. ABOVE ROOF SURFACE).

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL



ROOF EDGE - GUTTER WITH SLOTTED DRAIN BAR (BY OTHERS)

MATERIAL: EZ TPO

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

12/11/25

DETAIL NO.

EZT-RE-14

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com