



NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
2. INSTALL METAL WORK TO MANUFACTURER'S REQUIREMENTS OR SMACNA RECOMMENDATIONS.
3. EZ TPO CUT EDGE SEALANT REQUIRED AT ALL TPO EDGES WHERE SCRIP IS EXPOSED.
4. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
5. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (12.7 mm) FROM EDGE OF WOOD.
6. ON BALLASTED ROOFS, GRAVEL STOP HEIGHT MUST MEET OR EXCEED BALLAST OR PAVER HEIGHT (2" (50.8 mm) MIN. ABOVE ROOF SURFACE).
7. IF THE FLANGE OF METAL EDGE IS NOT COMPLETELY COVERED WITH COVER STRIP FLASHING. THEN AN ADDITIONAL PIECE OF FLASHING SHALL BE INSTALLED AT ALL METAL SPLICES. REFER TO EZT-RE-27.
8. USE OF 8" (203.2 mm) THERMOPLASTIC COVER STRIP IS ACCEPTABLE IN LIEU OF FIELD MEMBRANE.

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL

	EZ TPO ROOF EDGE WITH FASCIA METAL (BY OTHERS) WITH TPO FLASHING STRIP		MAXIMUM WARRANTY: 20 Years	
	MATERIAL: EZ TPO	ACCEPTABLE SYSTEMS: ALL	ISSUE / REVISION DATE: 04/20/2026	DETAIL NO. EZT-RE-20C
GENFLEX: (800) 443-4272 www.genflex.com			NOT TO SCALE	