

REQUIRED - APPLY EDGE CAULK ALONG THE ENTIRE PERIMETER OF THE T-JOINT COVER AND EXTEND A MIN. 3" (76.2 mm) PAST OVERLAPS IN EACH DIRECTION. (SEE NOTE #6)

EZ TPO PEEL & STICK FLASHING AND PRIMER AS REQUIRED (SEE NOTE #5)

EZ TPO PEEL & STICK FLASHING 5.5" x 5.5" (139.7 mm x 139.7 mm) MIN. WITH ROUNDED CORNERS OR TPO P&S T-JOINT (SEE NOTE #5)

WELDED FIELD SEAM

EZ TPO MEMBRANE

3" (76.2 mm) MIN. (SEE NOTE #2)

3" (76.2 mm) MIN. (SEE NOTE #2)

INSULATION

SUBSTRATE

WALL

CONTINUOUS BEAD OF EZ TPO EDGE CAULK (OPTIONAL)

DRIP/GRAVEL STOP EDGE METAL (BY OTHERS)

CONTINUOUS CLEAT (BY OTHERS)

WOOD NAILER (SEE NOTE #4)

NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
2. EDGE CAULK IS REQUIRED ALONG ENTIRE UPSLOPE EDGE OF PEEL & STICK FLASHING WHEN ROOF SLOPE IS 1" (25.4 mm) PER FOOT OR GREATER.
3. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (12.7 mm) FROM EDGE OF WOOD.
5. TPO PEEL & STICK FLASHING MUST EXTEND TO WITHIN 1/4" (6.35 mm) OF THE METAL EDGE AND COVER FASTENERS BY A MINIMUM OF 2" (50.8 mm).

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL



ROOF EDGE WITH EZ TPO PEEL & STICK FLASHING AT FIELD SEAM

MATERIAL: EZ TPO

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION DATE:

04/20/2026

DETAIL NO.

EZT-RE-26

GENFLEX: (800) 443-4272 www.genflex.com

NOT TO SCALE