



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
 2. EDGE CAULK IS REQUIRED ALONG ENTIRE UPSLOPE EDGE OF PEEL & STICK FLASHING WHEN ROOF SLOPE IS 1" (25.4 mm) PER FOOT OR GREATER.
 3. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES.
 4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (12.7 mm) FROM EDGE OF WOOD.
 5. TPO PEEL & STICK FLASHING MUST EXTEND TO WITHIN 1/4" (6.35 mm) OF THE METAL EDGE AND COVER FASTENERS BY A MINIMUM OF 2" (50.8 mm).
 6. WHERE METAL OVERLAPS ARE PRESENT, APPROPRIATE SEALANT (GENFLEX TERMINATION CAULK) MUST BE USED.

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL

	ROOF EDGE AT METAL SPLICE WITH EZ TPO PEEL & STICK FLASHING COVER		MAXIMUM WARRANTY: 20 Years	
	MATERIAL: EZ TPO	ACCEPTABLE SYSTEMS: ALL	ISSUE / REVISION DATE: 04/20/2026	DETAIL NO. EZT-RE-27
GENFLEX: (800) 443-4272 www.genflex.com			NOT TO SCALE	