



- NOTE:
1. REFER TO THE GENFLEX™ WEBSITE FOR MOST CURRENT INFORMATION.
 2. REGULAR MAINTENANCE OF COUNTER-FLASHING AND SEALANTS REQUIRED. NOT INCLUDED AS PART OF THE ROOFING SYSTEM LIMITED WARRANTY.
 3. METAL COUNTER-FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" (0.81 mm) MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
 4. INSTALL GENFLEX TERMINATION BAR WITH 1/4" (6.35 mm) GAP BETWEEN ADJOINING SECTIONS.
 5. TERMINATION BAR MUST BE CUT AT INSIDE AND INSIDE CORNERS. **DO NOT BEND AROUND CORNERS.**
 6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25.4 mm) MAX. OF ALL SECTION ENDS.
 7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.
 8. FOR SINGLE LIP TERMINATION BARS, ENSURE THAT THE TOP LIP FACES UPWARD

**WALLS / CURBS
(MASONRY /
CONCRETE
SUBSTRATE
ONLY)**

**MASONRY AND CONCRETE
WALLS / CURBS MUST BE
WATERPROOFED AND
MAINTAINED IN ORDER
FOR ANY SURFACE
MOUNTED TERMINATION
TO BE EFFECTIVE**

WARRANTY MEMBRANE REQUIREMENTS:
15-YEAR
 TPO - 45 MIL
20-YEAR
 TPO - 60 MIL



**TERMINATION WITH REGLET COUNTER-FLASHING
AND GENFLEX TERMINATION BAR**

MATERIAL: EZ TPO ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:
04/20/2026

DETAIL NO.
EZT-T-04

GENFLEX: (800) 443-4272 www.genflex.com

NOT TO SCALE