

WARRANTY MEMBRANE REQUIREMENTS:

UP TO 15-YEAR: 45 mil

UP TO 20-YEAR: 60 mil

**USE APPROPRIATE
TERMINATION**USE APPROPRIATE GENFLEX
MEMBRANE ADHESIVEPEEL & STICK RPS STRIP MUST EXTEND
1/2" (12.7 mm) BEYOND 2" METAL PLATE
(SEE NOTE)GENFLEX FASTENER AND 2" (50.8 mm)
METAL PLATE AT 12" (304.8 mm) O.C. MAX.
(SEE NOTE)

PEEL & STICK RPS STRIP (SEE NOTE)

ACCEPTABLE GENFLEX PRIMER

APPROPRIATE GENFLEX EPDM MEMBRANE

USE APPROPRIATE GENFLEX
MEMBRANE ADHESIVE. (SEE NOTE)

WALL / CURB

INSULATION

SUBSTRATE

NOTE:

1. REFER TO THE GENFLEX™ WEBSITE FOR THE MOST CURRENT INFORMATION.
2. MAXIMUM 10" (254 mm) LONG FASTENERS (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENTS).
3. IN CASE OF OBSTRUCTION REFER TO DETAIL BT-5.
4. REFER TO BT-14 & BT-15 FOR PEEL & STICK RPS STRIP LAYOUTS AT CORNERS.
5. MEMBRANE ADHESIVE REQUIRED BETWEEN PEEL & STICK RPS STRIP AND INSULATION ON ADHERED MEMBRANE SYSTEMS.

**BASE TIE-IN WITH PEEL & STICK RPS
AND 2" METAL PLATES FASTENED TO DECK**

MATERIAL: EPDM

ACCEPTABLE SYSTEMS: ALL

MAXIMUM WARRANTY: SEE TABLE

ISSUE / REVISION
DATE:

04/30/2026

DETAIL NO.

BT-01

NOT TO SCALE

GENFLEX: (800) 443-4272 www.genflex.com